Submitted to:

Quarterly Report

Fluid Bed Incinerator O&M Plan
East Bank WWTP
of the
Sewerage and Water Board
Of New Orleans

Air Permit # 2140-00089-02, 1996 AI#4859
NPDES Permit#LA0038091

April 1, 2009 to June 30, 2009

VEOLIA
WATER

VEOLIA
WATER

July 5, 2009

Marcia St. Martin
Director N.O. S&WB
S&WB of New Orleans
625 St. Joseph Street
New Orleans, LA 70130

Re: Quarterly Report – Fluid Bed Incineration, Operation and Maintenance

Dear Ms. St. Martin:

The enclosed report satisfies all conditions set forth in the Fluid Bed Incinerator's Operations and Maintenance Plan. Additionally, the report is accordance with 40 CFR Part 60, Subpart A&O; 40 CFR Part 60, Subpart A, δ60.7 and 40 CFR Part 503; 40 CFR Part 61, Subpart C and E.

Additionally, this report satisfies paragraph 61, section c of the Consent Decree (DOJ case no. 90-5-1-4043). Thereby, verifying that the operation and maintenance of the Fluid Bed Incinerator (FBI) was in accordance with the FBI's O&M Plan previously submitted.

I certify that the information contained in or accompanying this document is true, accurate, and complete. As to those identified portions of this document for which I cannot personally verify, I certify as acting official having supervisory responsibility for the persons who, acting under my direct instructions, made the certification, that this is true, accurate, and complete.

If any questions arise during the review of this report, please do hesitate to contact me at 504-277-5400.

Sincerely,

K. Servat

Kevin Servat
Project Manager
Veolia Water, New Orleans

Veolia Water North America Operating Services, LLC
6501 Florida Avenue, New Orleans, LA 70117
Tel: 504.277.5400 • Cell: 504.628.2628
www.veoliawaterna.com

Section One

503 Regulation's Report
April 1, 2009 to June 30, 2009
40 CFR Part 60, Subpart A&O

Data Submitted:

- ***Scrubber differential pressure***
- ***Scrubber exhaust oxygen level***
- ***Scrubber exhaust CO level***
- ***Scrubber exhaust Nox level***
- ***Scrubber water flow rate***
- ***Scrubber gas outlet temperature***
- ***Bed and freeboard temperatures***
- ***Rate of sludge charged into the incinerator***
- ***Moisture and volatile solids content***
- ***Dry tons incinerated***

Quarterly Incineration Report
East Bank
4/1/2009 TO 6/30/2009

Date	Sc V D/P "WC	Wet 02 % %	O2 Dry %	CO mg/L	NOx Ems mg/L	Sc H20 Flow gpm	Venturi out F	Air Flow SCFM
4/1/2009	35.5	6.7	10.5	2.6	35.7	741.1	188.4	7,010.9
4/2/2009	35.3	7.5	11.5	11.1	38.1	740.4	184.5	7,172.6
4/3/2009	35.3	8.5	12.2	5.9	36.3	758.9	179.8	7,538.5
4/4/2009	32.0	15.0	18.5	1.3	20.4	751.9	134.4	7,437.3
4/5/2009	31.6	15.1	18.5	1.4	5.1	730.8	131.4	7,429.2
4/6/2009	33.7	15.2	18.6	3.5	7.2	724.2	130.1	7,688.0
4/7/2009	34.3	15.2	18.8	2.6	8.5	734.3	130.0	7,761.2
4/8/2009	34.4	14.4	18.0	9.5	14.1	770.4	138.6	7,645.0
4/9/2009	32.6	12.5	16.6	0.5	32.4	761.4	158.8	6,625.5
4/10/2009	34.3	10.9	14.7	0.0	38.1	735.1	172.5	6,440.5
4/11/2009	34.4	11.2	15.3	0.0	39.0	720.7	170.8	6,540.9
4/12/2009	23.7	11.2	15.5	2.1	31.4	721.3	167.9	6,736.3
4/13/2009	32.9	10.1	14.0	1.2	35.2	719.7	174.4	6,833.9
4/14/2009	26.5	15.5	19.5	0.0	3.0	728.1	135.9	6,490.4
4/15/2009	34.6	10.2	15.7	0.7	35.3	727.8	174.1	6,468.7
4/16/2009	11.9	15.7	20.1	32.6	11.3	718.9	115.0	2,688.8
4/17/2009	31.5	12.0	15.8	0.5	51.5	775.7	165.4	6,481.4
4/18/2009	32.2	11.4	18.3	0.0	42.4	783.9	170.2	6,383.8
4/19/2009	31.3	11.1	20.2	10.4	50.5	781.9	171.1	6,194.3
4/20/2009	28.4	13.7	20.4	46.1	40.1	771.8	152.1	6,397.5
4/21/2009	28.6	13.2	21.2	0.0	55.2	764.2	156.7	6,316.1
4/22/2009	38.7	9.6	21.2	51.0	44.4	774.4	177.3	6,766.0
4/23/2009	30.2	8.1	20.9	96.1	36.0	772.7	184.7	7,192.7
4/24/2009	31.4	10.5	20.8	80.0	30.0	764.2	172.6	7,373.2
4/25/2009	33.5	10.0	21.0	75.0	29.4	763.2	178.1	6,847.6
4/26/2009	33.7	10.2	21.0	75.0	34.0	760.3	177.9	6,788.3
4/27/2009	37.5	9.4	13.7	15.5	41.2	754.8	179.8	6,725.4
4/28/2009	35.0	10.8	15.1	2.0	33.8	759.3	174.4	7,151.5
4/29/2009	30.5	11.7	15.7	3.0	52.0	758.0	168.2	6,190.4
4/30/2009	36.1	10.2	15.1	3.4	41.8	754.9	176.9	6,416.1
5/1/2009	34.4	10.9	15.8	3.5	40.5	758.7	172.6	6,409.3
5/2/2009	37.2	10.5	15.5	2.9	38.3	759.7	174.8	6,668.5
5/3/2009	39.0	11.0	15.8	2.4	37.0	760.4	172.3	7,091.7
5/4/2009	35.4	9.1	14.1	2.4	57.1	751.9	179.8	6,132.7
5/5/2009	34.5	11.1	16.1	2.6	44.0	748.1	172.3	6,473.1
5/6/2009	32.6	8.7	13.9	3.3	38.7	751.8	184.4	7,015.8
5/7/2009	6.0	16.1	19.4	5.6	7.0	152.4	124.7	1,284.2
5/8/2009	24.7	11.4	14.8	1.3	23.0	574.7	156.9	5,175.9
5/9/2009	35.6	8.0	12.3	1.1	32.6	803.4	185.3	7,352.6
5/10/2009	35.6	8.5	13.0	0.8	32.0	796.5	185.4	7,373.0
5/11/2009	35.4	9.1	13.9	1.9	35.9	786.5	181.2	7,389.7
5/12/2009	35.4	8.4	13.5	3.2	31.4	786.1	184.6	7,439.8
5/13/2009	31.1	11.8	17.0	28.2	31.1	657.1	163.0	5,519.1
5/14/2009	35.6	9.7	14.8	1.7	34.5	810.5	179.9	7,392.3
5/15/2009	35.6	10.0	15.2	1.3	33.7	816.9	178.9	7,436.9
5/16/2009	35.6	9.7	15.2	1.3	32.8	815.1	179.8	7,239.8
5/17/2009	35.6	10.9	16.0	1.6	39.5	847.7	175.2	7,555.7
5/18/2009	35.6	10.6	16.1	2.7	33.1	846.8	176.0	7,624.8
5/19/2009	35.6	10.6	15.1	1.6	39.5	835.6	176.0	7,521.7
5/20/2009	28.0	14.5	18.3	4.7	5.4	782.4	148.7	6,409.1
5/21/2009	27.4	14.6	18.1	0.3	3.6	764.1	149.0	6,330.3
5/22/2009	32.6	9.8	13.1	1.4	40.5	770.4	175.2	6,917.4
5/23/2009	35.6	9.5	12.6	0.0	40.1	761.2	183.1	7,484.5
5/24/2009	27.1	15.0	18.2	4.7	12.8	771.3	155.7	5,849.1
5/25/2009	28.8	11.2	14.4	3.2	26.5	822.3	163.7	6,125.9
5/26/2009	35.4	10.0	13.2	0.3	32.9	798.1	181.0	7,512.6
5/27/2009	35.3	10.1	13.6	10.4	27.5	813.4	178.2	7,222.4

Quarterly Incineration Report
East Bank
4/1/2009 TO 6/30/2009

Date	Sc V D/P "WC	Wet 02 % %	O2 Dry %	CO mg/L	NOx Ems mg/L	Sc H20 Flow gpm	Venturi out F	Air Flow SCFM
5/28/2009	34.4	9.8	13.5	5.6	23.6	815.6	177.9	7,003.2
5/29/2009	35.6	9.4	13.1	0.0	23.6	816.0	183.2	7,283.7
5/30/2009	35.4	8.6	13.0	0.0	33.1	814.1	184.5	6,813.4
5/31/2009	35.5	9.1	13.5	0.0	31.6	806.0	182.6	6,795.9
6/1/2009	35.5	9.4	12.3	0.0	32.7	814.9	181.7	7,055.8
6/2/2009	35.5	9.0	14.4	0.7	24.5	815.6	182.8	7,126.5
6/3/2009	35.4	9.8	14.2	7.1	28.2	804.7	179.6	7,354.8
6/4/2009	35.2	8.4	13.3	2.4	34.4	762.0	185.8	7,167.0
6/5/2009	32.2	9.8	14.9	9.3	31.7	709.5	171.8	6,351.0
6/6/2009	35.5	7.9	12.8	0.3	35.6	800.4	186.7	7,204.4
6/7/2009	35.5	8.6	13.9	0.0	35.8	802.5	184.4	7,163.6
6/8/2009	35.3	10.2	14.9	0.0	28.9	801.0	176.7	7,168.9
6/9/2009	35.5	8.6	13.5	0.2	32.1	799.3	185.0	7,055.3
6/10/2009	35.5	9.8	15.0	0.0	26.3	821.8	180.0	7,027.4
6/11/2009	35.5	9.6	14.9	0.0	26.5	789.8	181.1	7,020.6
6/12/2009	35.5	9.9	14.9	0.0	26.2	889.3	179.9	7,035.6
6/13/2009	35.5	9.7	15.1	0.0	22.9	902.4	180.5	7,031.2
6/14/2009	35.7	9.9	14.6	0.0	22.2	915.9	180.9	6,957.1
6/15/2009	36.0	10.3	15.0	0.0	18.8	931.5	180.2	6,940.7
6/16/2009	23.4	14.3	18.3	4.8	6.2	882.4	142.7	5,312.6
6/17/2009	34.8	9.8	14.1	6.2	31.7	854.6	180.2	7,191.6
6/18/2009	35.5	9.9	14.3	0.4	41.4	864.7	180.9	7,262.2
6/19/2009	35.4	9.5	14.4	1.9	26.0	861.8	182.4	6,960.3
6/20/2009	35.2	9.4	14.3	0.0	28.8	859.8	181.8	7,055.6
6/21/2009	35.5	8.2	13.2	2.0	25.8	836.0	187.4	7,049.4
6/22/2009	35.5	9.3	14.4	0.0	24.0	861.6	182.9	7,014.3
6/23/2009	35.5	7.3	12.7	2.1	21.5	878.3	191.6	7,180.6
6/24/2009	35.5	8.0	12.5	0.7	24.5	882.4	189.1	7,260.1
6/25/2009	35.5	8.1	12.5	0.1	25.7	880.9	188.9	7,274.2
6/26/2009	35.6	7.7	12.3	0.3	22.9	878.0	190.9	7,295.6
6/27/2009	35.6	8.3	13.0	0.4	23.7	885.0	187.8	7,245.1
6/28/2009	18.1	13.7	19.1	36.5	10.6	847.9	115.5	1,338.2
6/29/2009	25.7	9.6	14.3	17.5	21.4	857.1	179.0	7,114.6
6/30/2009	27.6	7.9	12.5	4.1	21.7	759.2	191.1	7,196.8
Average	32.9	10.5	15.5	8.0	29.9	784.3	171.9	6,758.1
Total	2,996.9	956.4	1,406.1	730.0	2,719.0	71,369.4	15,647.2	614,987.2
Minimum	6.0	6.7	10.5	0.0	3.0	152.4	115.0	1,284.2
Maximum	39.0	16.1	21.2	96.1	57.1	931.5	191.6	7,761.2

Quarterly Incineration Report
East Bank
4/1/2009 TO 6/30/2009

Date	Inc Temp F	Burn lbs Lbs	Cake % %	Cake %VS %	Sludge Inc Tons	Landfill tons
4/1/2009	1,498.6	57,845.24	22.4	60.1	28.9	
4/2/2009	1,497.0	59,746.43	22.1	60.5	29.9	
4/3/2009	1,487.1	51,749.43	22.0	59.0	25.9	
4/4/2009	1,500.0	1,168.83	22.0	58.4	0.6	
4/5/2009	1,499.5	0.00			0.0	
4/6/2009	1,498.6	1,182.20			0.6	
4/7/2009	1,499.4	956.41			0.5	
4/8/2009	1,499.1	3,580.46			1.8	
4/9/2009	1,498.7	48,102.91	23.9	49.0	24.1	
4/10/2009	1,499.1	44,822.43	22.1	56.8	22.4	
4/11/2009	1,499.3	49,844.39	24.1	49.5	24.9	
4/12/2009	1,496.8	58,266.95	21.4	73.8	29.1	
4/13/2009	1,497.7	46,337.61	22.5	38.2	23.2	
4/14/2009	1,500.2	1,044.23	24.6	60.2	0.5	
4/15/2009	1,499.8	66,256.75	25.9	87.9	33.1	
4/16/2009	1,447.6	27,987.37	21.8	59.8	14.0	
4/17/2009	1,500.3	30,252.73	21.8	61.6	15.1	
4/18/2009	1,498.5	27,457.40	21.4	61.8	13.7	
4/19/2009	1,499.3	30,078.19	21.3	62.6	15.0	
4/20/2009	1,499.0	24,653.72	21.6	61.7	12.3	
4/21/2009	1,499.6	62,358.25	22.7	60.1	31.2	
4/22/2009	1,498.3	66,865.68	23.0	60.0	33.4	
4/23/2009	1,498.4	61,567.08	21.8	58.4	30.8	
4/24/2009	1,479.3	73,113.44	22.3	58.6	36.6	
4/25/2009	1,498.0	68,881.81	22.0	57.7	34.4	
4/26/2009	1,498.9	43,343.85	22.2	57.1	21.7	
4/27/2009	1,498.5	61,093.24	20.4	61.2	30.5	
4/28/2009	1,498.9	51,651.12	21.5	59.8	25.8	
4/29/2009	1,500.9	52,676.91	21.9	59.0	26.3	
4/30/2009	1,499.0	63,341.97	21.4	60.1	31.7	
5/1/2009	1,499.6	32,113.20	21.0	56.0	16.1	
5/2/2009	1,499.8	43,089.82	20.3	57.0	21.5	
5/3/2009	1,497.8	48,353.59	20.5	55.8	24.2	
5/4/2009	1,499.8	34,204.94	20.9	56.8	17.1	
5/5/2009	1,499.9	30,739.77	21.6	56.0	15.4	
5/6/2009	1,499.3	42,580.39	23.3	61.4	21.3	
5/7/2009	1,387.6	7,109.93	21.3	57.1	3.6	
5/8/2009	1,426.6	60,658.49	22.5	56.4	30.3	
5/9/2009	1,498.1	47,982.89	21.6	60.4	24.0	
5/10/2009	1,497.3	45,191.86	20.5	62.4	22.6	
5/11/2009	1,499.9	49,497.19	20.1	63.1	24.7	
5/12/2009	1,477.7	49,519.61	21.4	63.7	24.8	
5/13/2009	1,499.3	28,092.14	20.9	63.2	14.0	
5/14/2009	1,494.9	39,415.09	22.0	64.3	19.7	
5/15/2009	1,497.3	47,302.61	21.8	63.4	23.7	
5/16/2009	1,494.3	61,993.31	25.2	66.6	31.0	
5/17/2009	1,503.1	37,833.20	20.1	60.6	18.9	
5/18/2009	1,493.8	39,587.68	21.1	61.7	19.8	
5/19/2009	1,488.9	41,402.36	21.8	62.4	20.7	
5/20/2009	1,484.5		22.3	61.5		
5/21/2009	1,499.9					
5/22/2009	1,489.9	26,462.40	22.4	60.7	13.2	
5/23/2009	1,482.0	36,754.98	21.1	60.5	18.4	
5/24/2009	1,499.6	5,554.92	27.5	60.1	2.8	
5/25/2009	1,457.5	29,487.32	20.8	59.6	14.7	
5/26/2009	1,499.1	38,594.73	20.8	60.7	19.3	
5/27/2009	1,481.1	35,927.25	22.2	59.5	18.0	

Quarterly Incineration Report
East Bank
4/1/2009 TO 6/30/2009

Date	Inc Temp F	Burn lbs Lbs	Cake % %	Cake %VS %	Sludge Inc Tons	Landfill tons
5/28/2009	1,459.2	74,725.23	22.1	60.5	37.4	
5/29/2009	1,482.3	42,957.00	21.9	60.2	21.5	
5/30/2009	1,486.1	44,374.97	22.3	60.1	22.2	
5/31/2009	1,496.7	48,958.26	21.1	59.8	24.5	
6/1/2009	1,491.9	39,652.60	22.2	60.3	19.8	
6/2/2009	1,499.0	61,369.51	21.0	61.0	30.7	
6/3/2009	1,494.6	18,119.20	21.6	60.3	9.1	
6/4/2009	1,502.9	74,995.42	22.6	61.1	37.5	
6/5/2009	1,502.4	40,580.46	21.8	60.0	20.3	
6/6/2009	1,484.8	50,979.40	20.0	60.5	25.5	
6/7/2009	1,492.8	58,274.25	19.2	61.0	29.1	
6/8/2009	1,493.5	41,774.94	20.0	61.4	20.9	
6/9/2009	1,491.5	47,082.59	20.2	61.5	23.5	
6/10/2009	1,498.9	34,915.08	21.0	60.0	17.5	
6/11/2009	1,499.7	41,655.96	25.5	58.6	20.8	
6/12/2009	1,492.4	41,494.87	21.1	59.7	20.7	
6/13/2009	1,492.2	42,343.25	21.4	57.7	21.2	
6/14/2009	1,493.5	37,455.54	21.8	58.1	18.7	
6/15/2009	1,493.9	6,626.13	21.1	56.5	3.3	
6/16/2009	1,426.6	26,622.03	21.4	52.4	13.3	
6/17/2009	1,496.8	40,957.82	21.6	53.8	20.5	
6/18/2009	1,503.1	46,762.63	21.7	53.2	23.4	
6/19/2009	1,499.3	39,272.98	21.8	62.0	19.6	
6/20/2009	1,493.1	73,904.06	21.3	56.3	37.0	
6/21/2009	1,489.9	44,598.90	21.5	57.4	22.3	
6/22/2009	1,489.0	48,097.70	22.2	57.4	24.0	
6/23/2009	1,498.0	51,820.22	21.4	59.8	25.9	
6/24/2009	1,501.1	39,969.45	21.3	57.5	20.0	
6/25/2009	1,503.0	49,209.25	21.2	59.2	24.6	
6/26/2009	1,493.9	63,460.23	20.5	60.0	31.7	
6/27/2009	1,500.5	32,968.90	20.8	58.6	16.5	
6/28/2009	1,310.9	1,229.71	21.5	60.5	0.6	
6/29/2009	1,483.8	40,398.18	21.8	58.2	20.2	
6/30/2009	1,500.2	71,724.73	26.3	58.4	35.9	
Average	1,489.8	41,741.66	21.9	59.6	20.9	
Total	135,571.5	3,715,008.16	1,879.3	5,126.8	1,857.5	0.0
Minimum	1,310.9	0.00	19.2	38.2	0.0	
Maximum	1,503.1	74,995.42	27.5	87.9	37.5	

Section Two

Quarterly CO & NOx Exceedence Report
April 1 , 2009 to June 30, 2009
40 CFR Part 60, Subpart A, δ60.7 and
40 CFR Part 503

Data Submitted:

- ***CO & NOx average quarterly exceedence report***
- ***Monthly dry oxygen CEM report***
- ***Monthly moisture CEM report***
- ***Monthly CO CEM report***
- ***Monthly NOx CEM report***

Quarterly Exceedence Report

New Orleans - East Bank WWTP
Apr 01, 2009

Date/Time	Description	Duration	Peek Value	Operator	Reason
04/03/2009 00:06:07	CO > 100 ppm	00:30:59	110.70	Steven J RobinsoAdjusting Air Flow	Adjusting Air Flow
04/16/2009 16:33:02	CO > 100 ppm	00:01:00	109.90	Herbert Thomas	Adjusting Feed Rate
04/16/2009 20:34:02	CO > 100 ppm	00:06:00	102.60	Billy Howard	Adjusting Feed Rate
04/16/2009 23:46:02	CO > 100 ppm	01:44:03	192.00	Billy Howard	Adjusting Feed Rate
04/17/2009 02:11:07	CO > 100 ppm	00:45:00	139.50	Billy Howard	Adjusting Feed Rate
04/20/2009 04:36:05	CO > 100 ppm	00:07:00	104.20	Steven J Robinso	Adjusting Feed Rate
04/20/2009 04:46:05	CO > 100 ppm	00:37:57	131.70	Steven J Robinso	Adjusting Feed Rate
04/20/2009 09:07:03	CO > 100 ppm	05:59:03	221.70	Jawanda Trimont	Adjusting Feed Rate
04/20/2009 14:56:06	NOX > 100 ppm	01:12:00	255.70	Jawanda Trimont	Maintenance Repair
04/22/2009 07:25:03	CO > 100 ppm	00:53:00	141.70	Herbert Thomas	Adjusting Feed Rate
04/22/2009 12:11:03	CO > 100 ppm	02:47:01	500.00	Herbert Thomas	Adjusting Feed Rate
04/22/2009 16:33:06	CO > 100 ppm	01:14:55	328.10	Herbert Thomas	Adjusting Feed Rate
04/23/2009 07:21:04	CO > 100 ppm	00:25:00	100.40	Herbert Thomas	Adjusting Feed Rate
04/23/2009 19:14:05	CO > 100 ppm	00:19:00	119.30	Billy Howard	Adjusting Feed Rate
04/23/2009 23:21:02	CO > 100 ppm	03:20:02	258.20	Billy Howard	Adjusting Feed Rate
04/24/2009 03:02:04	CO > 100 ppm	04:34:59	426.80	Billy Howard	Adjusting Feed Rate
04/24/2009 10:43:02	CO > 100 ppm	06:11:59	491.50	Herbert Thomas	Adjusting Feed Rate
04/24/2009 20:06:04	CO > 100 ppm	01:01:59	208.30	Billy Howard	Adjusting Feed Rate
04/24/2009 23:26:03	CO > 100 ppm	04:38:01	500.00	Billy Howard	Adjusting Feed Rate
04/25/2009 04:07:04	CO > 100 ppm	00:05:00	154.40	Billy Howard	Adjusting Feed Rate
04/25/2009 05:44:02	CO > 100 ppm	00:40:04	236.00	Billy Howard	Adjusting Feed Rate
04/25/2009 06:28:06	CO > 100 ppm	00:13:00	174.60	Billy Howard	Adjusting Feed Rate
04/25/2009 06:43:06	CO > 100 ppm	00:03:00	112.90	Billy Howard	Adjusting Feed Rate
04/25/2009 08:13:04	CO > 100 ppm	00:02:00	102.60	Herbert Thomas	Adjusting Feed Rate
04/25/2009 08:17:04	CO > 100 ppm	00:04:00	106.90	Herbert Thomas	Adjusting Feed Rate
04/25/2009 08:23:04	CO > 100 ppm	00:02:00	103.50	Herbert Thomas	Adjusting Feed Rate
04/25/2009 08:27:04	CO > 100 ppm	01:45:57	183.90	Herbert Thomas	Adjusting Feed Rate
04/25/2009 10:21:01	CO > 100 ppm	00:05:00	101.80	Herbert Thomas	Adjusting Feed Rate
04/25/2009 10:30:01	CO > 100 ppm	00:07:00	106.50	Herbert Thomas	Adjusting Feed Rate
04/25/2009 10:40:01	CO > 100 ppm	17:52:04	500.00	Herbert Thomas	Adjusting Feed Rate
04/26/2009 12:01:05	CO > 100 ppm	20:36:01	500.00	Jawanda Trimont	Adjusting Feed Rate
04/30/2009 08:32:05	NOX > 100 ppm	00:52:00	120.60	Herbert Thomas	Maintenance Repair
05/07/2009 11:45:02	CO > 100 ppm	27:06:03	500.00	Jawanda Trimont	Adjusting Feed Rate
05/13/2009 12:35:02	CO > 100 ppm	04:15:02	138.90	Jawanda Trimont	Adjusting Feed Rate
05/28/2009 06:07:04	CO > 100 ppm	00:27:57	236.70	Steven J Robinso	Adjusting Feed Rate
05/28/2009 06:38:05	CO > 100 ppm	00:05:59	187.50	Steven J Robinso	Adjusting Feed Rate

Quarterly Exceedence Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Date/Time	Description	Duration	Peek Value	Operator	Reason
05/28/2009 07:27:02	CO > 100 ppm	00:59:00	147.90	Carl Kelly	Adjusting Feed Rate
06/05/2009 09:05:02	CO > 100 ppm	00:31:00	136.80	Jawanda Trimont	Adjusting Feed Rate
06/17/2009 09:58:06	CO > 100 ppm	00:13:00	105.20	Herbert Thomas	Maintenance Repair
06/28/2009 00:20:02	CO > 100 ppm	02:04:00	500.00	Joseph Edwards	Adjusting Air Flow
06/28/2009 08:53:02	CO > 100 ppm	00:54:00	124.40	Donald Trotter	Adjusting Feed Rate
06/28/2009 13:15:01	CO > 100 ppm	00:47:01	143.30	Donald Trotter	Maintenance Repair
06/29/2009 01:17:05	CO > 100 ppm	00:59:00	188.40	Billy Howard	FBI Offline
06/29/2009 07:17:03	CO > 100 ppm	01:19:00	332.50	Carl Kelly	Maintenance Repair

Monthly Exceedence Report

New Orleans - East Bank WWTP
April 2009

Date/Time	Description	Duration	Peek Value	Operator	Reason
04/03/2009 00:06:07	CO > 100 ppm	00:30:59	110.70	Steven J RobinsoAdjusting Air Flow	Adjusting Air Flow
04/16/2009 16:33:02	CO > 100 ppm	00:01:00	109.90	Herbert Thomas	Adjusting Feed Rate
04/16/2009 20:34:02	CO > 100 ppm	00:06:00	102.60	Billy Howard	Adjusting Feed Rate
04/16/2009 23:46:02	CO > 100 ppm	01:44:03	192.00	Billy Howard	Adjusting Feed Rate
04/17/2009 02:11:07	CO > 100 ppm	00:45:00	139.50	Billy Howard	Adjusting Feed Rate
04/20/2009 04:36:05	CO > 100 ppm	00:07:00	104.20	Steven J Robinso	Adjusting Feed Rate
04/20/2009 04:46:05	CO > 100 ppm	00:37:57	131.70	Steven J Robinso	Adjusting Feed Rate
04/20/2009 09:07:03	CO > 100 ppm	05:59:03	221.70	Jawanda Trimont	Adjusting Feed Rate
04/20/2009 14:56:06	NOX > 100 ppm	01:12:00	255.70	Jawanda Trimont	Maintenance Repair
04/22/2009 07:25:03	CO > 100 ppm	00:53:00	141.70	Herbert Thomas	Adjusting Feed Rate
04/22/2009 12:11:03	CO > 100 ppm	02:47:01	500.00	Herbert Thomas	Adjusting Feed Rate
04/22/2009 16:33:06	CO > 100 ppm	01:14:55	328.10	Herbert Thomas	Adjusting Feed Rate
04/23/2009 07:21:04	CO > 100 ppm	00:25:00	100.40	Herbert Thomas	Adjusting Feed Rate
04/23/2009 19:14:05	CO > 100 ppm	00:19:00	119.30	Billy Howard	Adjusting Feed Rate
04/23/2009 23:21:02	CO > 100 ppm	03:20:02	258.20	Billy Howard	Adjusting Feed Rate
04/24/2009 03:02:04	CO > 100 ppm	04:34:59	426.80	Billy Howard	Adjusting Feed Rate
04/24/2009 10:43:02	CO > 100 ppm	06:11:59	491.50	Herbert Thomas	Adjusting Feed Rate
04/24/2009 20:06:04	CO > 100 ppm	01:01:59	208.30	Billy Howard	Adjusting Feed Rate
04/24/2009 23:26:03	CO > 100 ppm	04:38:01	500.00	Billy Howard	Maintinance Repair
04/25/2009 04:07:04	CO > 100 ppm	00:05:00	154.40	Billy Howard	Maintinance Repair
04/25/2009 05:44:02	CO > 100 ppm	00:40:04	236.00	Billy Howard	Maintinance Repair
/25/2009 06:28:06	CO > 100 ppm	00:13:00	174.60	Billy Howard	Maintinance Repair
04/25/2009 06:43:06	CO > 100 ppm	00:03:00	112.90	Billy Howard	Maintinance Repair
04/25/2009 08:13:04	CO > 100 ppm	00:02:00	102.60	Herbert Thomas	Maintinance Repair
04/25/2009 08:17:04	CO > 100 ppm	00:04:00	106.90	Herbert Thomas	Maintinance Repair
04/25/2009 08:23:04	CO > 100 ppm	00:02:00	103.50	Herbert Thomas	Maintinance Repair
04/25/2009 08:27:04	CO > 100 ppm	01:45:57	183.90	Herbert Thomas	Maintinance Repair
04/25/2009 10:21:01	CO > 100 ppm	00:05:00	101.80	Herbert Thomas	Maintinance Repair
04/25/2009 10:30:01	CO > 100 ppm	00:07:00	106.50	Herbert Thomas	Maintinance Repair
04/25/2009 10:40:01	CO > 100 ppm	17:52:04	500.00	Herbert Thomas	Maintinance Repair
04/26/2009 12:01:05	CO > 100 ppm	20:36:01	500.00	Jawanda Trimont	Maintinance Repair
04/30/2009 08:32:05	NOX > 100 ppm	00:52:00	120.60	Herbert Thomas	Maintenance Repair

Monthly O2 CEM Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Hourly O2 Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	12.1	12.1	12.2	12.2	12.3	12.4	12.5	12.6	12.7	12.7	12.8	4.5	10.5	10.9	10.5	10.6	10.4	11.0	10.8	10.3	10.7	10.5	9.9	11.0
2	9.8	9.8	10.1	10.6	11.4	10.5	10.1	10.2	10.7	10.8	11.1	13.3	14.5	12.0	10.4	10.0	9.5	9.8	14.6	11.1	8.7	10.6	10.6	11.4
3	12.0	13.7	11.3	11.3	11.7	11.9	12.1	12.0	12.3	10.0	12.0	11.1	11.5	11.4	11.2	11.0	10.5	10.7	11.5	9.3	13.2	10.6	11.2	11.9
4	11.4	11.4	13.2	14.0	10.3	15.9	18.4	18.2	19.1	18.3	18.9	18.6	18.1	18.5	18.6	18.8	18.0	18.5	18.7	18.1	17.9	18.6	18.5	18.6
5	18.7	18.6	18.6	18.6	18.6	18.6	18.7	18.6	18.6	18.6	18.7	18.7	18.6	18.6	18.4	18.4	18.4	18.6	18.6	18.7	18.7	18.7	18.6	18.5
6	18.4	18.5	18.4	18.4	18.3	18.4	18.5	18.4	18.4	18.5	18.5	18.5	18.6	18.6	18.6	18.6	17.9	18.8	18.6	18.6	18.6	18.5	18.6	18.6
7	18.6	18.6	18.6	18.6	18.6	18.7	18.6	18.6	18.7	18.7	18.7	17.7	18.8	18.9	18.9	18.9	18.8	18.8	18.8	18.9	19.0	19.0	19.0	19.0
8	18.9	19.0	18.9	18.9	18.9	18.9	18.8	18.9	18.9	18.9	19.0	16.1	17.6	16.2	15.7	18.4	18.2	18.2	18.1	18.3	18.3	18.3	18.3	18.3
9	18.3	18.1	18.1	18.1	18.0	17.9	17.9	18.5	19.1	19.1	18.9	17.5	16.9	16.2	15.5	15.8	15.7	16.4	15.1	15.1	15.7	16.2	16.5	16.6
10	16.8	16.6	16.7	16.4	16.7	16.5	16.6	16.4	16.1	15.2	15.9	15.2	14.7	14.4	14.0	14.2	13.7	15.2	14.1	14.1	14.2	14.4	14.5	14.7
11	14.6	14.7	14.4	14.9	14.5	15.0	15.1	15.3	15.2	15.5	15.5	15.6	15.4	15.2	14.9	14.8	15.4	14.7	14.5	14.7	14.7	14.8	15.0	15.3
12	15.4	14.3	15.1	16.8	16.4	15.8	16.2	15.8	15.6	14.7	14.8	15.2	15.0	16.2	18.6	15.3	15.8	16.8	19.1	15.7	15.1	15.2	15.5	15.5
13	15.9	15.2	14.7	14.6	14.4	14.2	14.4	14.4	13.7	18.3	17.4	12.4	11.7	11.8	11.6	11.9	11.9	11.3	11.5	12.5	11.5	11.9	12.7	14.9
14	14.7	14.5	15.0	15.8	16.3	16.7	17.2	19.0	19.4	19.3	19.4	19.4	19.5	19.3	19.3	19.4	19.2	19.2	19.2	19.2	19.4	19.3	19.4	19.4
15	19.5	19.7	19.8	19.9	19.9	20.0	19.6	19.1	17.6	15.7	15.5	15.4	16.2	15.0	15.2	15.6	15.6	15.9	16.2	16.3	15.9	15.6	15.2	15.1
16	14.8	14.8	14.9	14.7	14.7	15.6	15.2	19.8	20.2	19.9	16.5	17.3	17.9	18.1	18.4	19.1	21.3	21.4	21.5	21.4	21.0	20.9	21.3	21.3
17	21.1	21.1	21.0	21.1	21.4	21.4	21.3	17.2	18.0	16.8	17.1	16.3	14.9	14.8	15.1	15.0	15.2	15.3	15.1	15.1	14.9	15.1	15.5	15.4
18	15.4	16.4	17.0	17.0	16.8	16.7	16.1	15.4	16.6	16.9	16.4	16.1	16.3	16.4	16.7	16.5	16.7	15.8	16.7	19.5	19.6	19.5	19.5	19.9
[illegible]	19.9	20.1	20.1	20.2	20.2	20.3	19.9	19.7	19.8	19.9	20.0	20.0	20.0	20.0	20.0	20.0	20.1	20.1	20.1	20.2	20.2	20.3	20.4	20.4
20	20.4	20.5	20.6	20.7	20.8	20.8	20.3	20.3	20.3	20.7	21.1	21.1	21.1	21.0	21.0	12.8	11.4	21.2	21.2	21.2	21.2	21.2	21.4	21.4
21	21.4	21.5	21.4	21.4	21.4	21.5	21.0	21.2	21.5	21.5	21.3	21.2	21.1	21.1	21.1	21.1	21.1	21.2	21.3	21.3	21.3	21.3	21.3	21.3
22	21.3	21.3	21.3	21.3	21.3	21.3	20.3	20.0	21.0	21.2	21.2	21.2	21.1	21.0	20.9	20.9	20.8	21.0	21.1	21.3	21.3	21.3	21.4	21.4
23	21.4	21.4	21.4	21.4	21.4	21.4	20.9	20.2	21.1	21.4	21.5	21.5	21.4	21.3	21.3	21.4	20.5	20.6	20.7	20.7	20.7	20.7	20.7	20.7
24	20.7	20.8	20.8	20.9	21.0	20.7	20.6	20.6	20.7	20.0	20.3	20.7	20.8	20.9	20.9	21.0	21.0	20.8	20.7	20.6	20.7	20.8	20.8	20.8
25	20.9	21.0	21.0	21.0	21.0	21.1	20.8	21.0	21.0	21.0	21.0	21.1	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0
26	21.0	21.0	21.0	21.0	21.0	21.1	21.1	21.1	21.1	21.1	21.1	21.1	21.1	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0
27	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	17.4	13.9	14.9	18.8	15.8	13.7	14.1	12.6	10.2	11.6	11.5	10.9	11.9	11.8	12.8
28	12.9	13.4	13.7	13.7	13.3	13.3	12.8	13.4	13.2	12.6	12.9	13.8	14.3	14.1	15.4	16.5	16.2	15.9	15.7	15.8	15.7	15.7	15.6	15.5
29	15.5	15.7	15.5	15.3	15.2	15.3	15.1	15.4	14.9	15.0	15.1	14.3	13.8	14.0	15.7	13.2	15.4	15.5	15.5	15.8	15.8	16.2	16.4	16.1
30	16.2	16.4	17.2	17.4	17.0	17.2	16.5	17.0	14.5	10.9	15.5	13.4	16.6	15.8	14.7	15.0	15.1	15.2	15.2	15.2	16.3	15.6	15.4	15.5

Monthly O2 Analyzer Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Hourly O2 Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	8.1	8.4	8.5	10.9	13.9	8.8	8.8	8.4	7.3	7.1	6.9	7.3	7.4	7.5	6.7	6.3	6.2	6.4	6.1	6.0	6.0	6.7	6.2	7.0
2	6.4	6.4	6.7	6.8	6.8	6.6	6.6	6.5	6.4	6.7	6.6	6.7	7.3	6.6	6.6	5.6	5.6	5.9	11.1	7.6	5.3	6.8	6.6	7.5
3	8.9	11.1	8.4	8.3	8.5	8.6	8.4	8.6	8.7	6.7	8.6	7.3	7.3	7.2	7.0	7.1	6.6	6.7	7.3	5.3	10.2	8.0	7.5	8.5
4	7.9	8.1	9.6	10.8	6.9	12.5	14.8	14.3	15.4	14.6	15.4	15.1	14.8	14.9	15.1	15.2	14.5	15.1	15.2	14.8	14.2	15.1	15.1	15.2
5	15.2	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.2	15.1	15.2	15.2
6	15.2	15.2	15.2	15.2	15.2	15.2	14.8	15.2	15.2	15.2	15.2	15.3	15.3	15.3	15.2	15.3	14.5	15.3	15.3	15.3	15.3	15.3	15.3	15.3
7	15.3	15.3	15.3	15.3	15.3	15.3	14.5	15.3	15.3	15.3	15.3	14.3	15.1	15.4	15.3	15.3	15.3	15.3	15.3	15.2	15.3	15.3	15.3	15.3
8	15.3	15.3	15.2	15.2	15.2	15.2	14.4	15.2	15.2	15.2	15.2	12.8	13.7	13.0	11.8	15.0	14.7	14.6	14.6	14.6	14.7	14.8	14.7	14.7
9	14.7	14.6	14.6	14.6	14.5	14.5	13.9	14.8	15.1	15.0	14.8	13.1	12.4	11.6	10.8	11.2	11.2	12.4	11.1	11.1	11.7	12.3	12.7	12.6
10	12.8	12.8	12.8	12.6	12.9	12.7	13.0	12.6	12.2	11.3	12.1	11.3	10.9	10.8	10.5	10.6	10.2	11.5	10.5	10.5	10.4	10.6	10.6	10.7
11	10.5	10.7	10.7	10.9	10.7	11.1	10.8	11.1	10.9	11.1	11.0	11.1	10.8	10.9	10.7	10.7	11.4	10.6	10.5	10.6	10.7	10.6	10.9	10.7
12	10.9	10.5	10.8	12.5	12.5	12.7	12.9	12.8	12.7	11.9	12.0	12.4	12.2	13.2	15.5	12.0	12.5	13.4	15.5	10.3	9.2	9.2	9.3	9.5
13	9.9	9.7	9.9	9.8	9.6	9.5	9.6	9.6	9.4	14.6	13.7	8.4	7.9	7.8	7.9	8.0	8.2	7.6	7.7	8.5	7.6	7.8	8.5	10.8
14	11.0	11.1	11.5	11.8	12.1	12.0	12.6	15.3	15.3	15.6	15.6	15.6	15.6	15.6	15.6	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5	15.5
15	15.4	15.4	15.4	15.4	15.4	15.4	14.7	15.4	13.6	10.7	10.3	10.2	11.3	10.5	10.6	11.0	11.1	11.3	11.5	11.5	11.1	10.4	9.8	9.0
16	8.4	8.2	7.7	7.7	7.5	7.7	7.9	15.0	15.7	15.6	10.8	11.8	12.5	12.7	13.1	14.1	17.3	16.6	16.8	16.9	17.0	17.2	17.2	17.2
17	17.3	17.4	17.2	17.2	17.3	17.2	17.8	13.1	13.6	12.2	12.1	12.1	12.0	11.7	11.9	11.9	12.0	11.9	12.0	12.1	12.1	12.2	12.1	12.1
18	12.1	12.3	12.5	11.6	11.2	11.1	11.2	11.3	11.3	11.3	11.5	11.4	11.4	11.2	11.4	11.4	11.3	11.3	11.2	11.4	11.3	11.4	11.3	11.3
[illegible]	11.3	11.4	11.3	11.4	11.4	11.3	11.4	11.4	11.3	11.2	11.1	11.2	11.2	11.1	11.0	10.8	10.8	10.8	10.6	10.9	10.6	10.9	10.9	11.1
20	11.1	11.0	11.1	11.5	11.5	11.7	11.6	11.6	11.6	13.6	15.8	15.6	15.5	15.6	15.6	15.5	15.5	15.5	15.5	12.3	12.1	12.0	12.0	12.2
21	12.4	12.6	12.7	12.9	13.0	13.0	13.2	13.3	13.5	14.6	13.1	13.1	12.9	12.8	13.0	12.8	12.9	13.0	13.0	13.0	13.1	13.0	13.1	13.2
22	13.1	13.2	13.2	13.4	13.3	13.4	13.3	13.5	13.4	13.3	13.4	13.3	13.0	12.6	10.5	8.7	9.4	8.6	8.3	8.3	8.4	6.2	8.2	8.2
23	8.3	8.1	7.9	7.6	7.8	8.6	9.3	8.6	9.4	9.9	8.7	8.5	9.4	7.0	7.3	8.8	9.2	10.4	8.8	8.3	8.1	7.6	7.1	6.5
24	6.3	6.2	6.3	9.5	13.1	5.9	5.2	5.7	7.4	7.8	7.9	7.6	7.7	8.6	9.8	9.8	10.3	9.6	9.1	8.6	9.0	10.5	9.5	9.2
25	12.1	12.2	14.1	15.2	13.6	17.9	12.5	11.8	10.5	10.3	10.2	10.2	10.3	10.2	10.1	10.1	10.0	9.6	9.5	9.5	9.4	9.2	9.1	9.5
26	9.5	9.6	9.6	9.9	10.9	9.8	12.2	10.2	10.3	10.2	10.4	10.2	10.1	10.0	10.2	10.1	9.6	9.6	10.1	9.8	9.9	10.0	10.3	10.3
27	10.4	10.2	10.3	10.2	10.2	10.4	10.5	10.4	10.7	10.2	10.1	11.4	15.7	12.6	10.2	10.6	9.1	7.1	8.3	8.2	8.1	8.1	8.3	8.4
28	8.2	8.6	8.6	8.7	8.3	8.7	8.6	9.1	8.8	8.6	8.6	9.3	9.6	9.6	10.9	12.1	11.9	12.0	11.7	11.5	11.3	11.2	11.3	11.4
29	11.3	11.2	11.2	11.1	11.2	11.0	11.3	11.5	10.5	10.5	10.8	10.8	10.7	10.6	12.1	9.3	11.5	11.4	11.5	11.7	11.7	11.8	11.9	11.6
30	11.5	11.6	12.8	13.1	12.9	12.9	13.3	13.2	10.5	10.2	10.5	9.8	11.6	11.1	9.8	10.0	10.0	10.2	10.2	10.3	9.8	10.3	10.0	10.0

Monthly Moisture CEM Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Hourly Moisture Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	32.7	30.8	30.2	26.2	24.6	29.4	30.1	33.3	42.7	44.2	45.7	1.$	28.7	31.3	35.9	39.3	40.4	42.0	43.7	41.9	43.5	35.4	36.8	35.9
2	34.6	34.2	34.0	35.6	39.7	37.2	34.5	35.7	40.2	38.1	40.7	48.7	48.9	43.1	36.1	43.8	40.5	40.0	27.8	33.1	38.7	35.4	38.2	34.4
3	31.3	20.0	25.8	25.9	26.7	27.2	30.1	28.0	28.8	34.4	29.1	34.3	36.5	36.7	37.0	35.1	36.4	37.7	36.5	44.9	25.5	25.1	35.3	29.2
4	31.0	28.6	27.2	22.8	33.5	22.0	18.8	21.3	19.1	19.7	18.7	18.8	18.3	19.4	18.7	19.2	19.4	18.4	18.8	18.8	20.8	18.7	18.3	18.3
5	18.9	18.5	18.9	19.0	19.0	19.0	18.7	18.8	18.7	18.9	19.0	19.0	18.6	18.5	17.9	17.9	18.0	18.6	18.8	19.0	18.8	18.9	18.2	17.6
6	17.5	17.5	17.3	17.0	17.0	17.2	19.5	17.4	17.4	17.6	17.6	17.7	18.0	18.1	18.1	18.1	22.0	18.6	18.3	18.0	17.8	17.8	17.9	17.8
7	17.9	17.8	17.8	17.8	18.1	18.2	22.1	17.8	18.3	18.3	18.1	21.7	19.9	19.1	19.1	19.2	19.1	18.9	18.9	19.2	19.2	19.3	19.5	19.3
8	19.2	19.3	19.3	19.2	19.2	19.2	23.1	19.1	19.0	19.3	20.0	21.4	22.0	19.7	24.2	18.9	19.0	19.4	19.7	19.7	19.4	19.5	19.5	19.7
9	19.5	19.4	19.3	19.5	19.1	18.7	22.2	20.1	20.9	21.6	21.8	25.1	27.0	28.3	31.1	29.1	28.7	25.0	27.0	26.3	25.3	23.7	23.2	23.9
10	23.8	23.0	23.5	23.1	22.8	23.2	21.1	23.4	24.5	25.8	24.1	25.3	25.9	25.2	25.2	25.5	25.6	24.0	25.5	25.4	26.8	26.8	27.1	27.5
11	28.3	27.2	26.0	27.0	26.0	25.9	26.1	26.9	28.1	28.1	28.6	28.8	29.6	28.2	28.3	27.7	26.0	27.9	27.5	27.5	27.0	28.2	27.2	30.1
12	29.4	26.3	28.0	25.7	23.5	19.6	19.7	18.9	18.4	19.2	18.8	18.5	18.8	18.3	16.8	22.2	21.1	20.5	19.0	35.8	38.9	39.3	39.8	38.1
13	37.5	35.9	32.8	32.9	33.6	33.0	32.0	33.2	31.7	21.8	21.2	32.4	32.2	33.8	32.1	32.1	31.6	32.6	33.1	31.6	34.4	34.8	33.2	27.8
14	25.2	23.4	23.0	24.8	25.5	28.1	25.5	19.4	21.2	19.4	19.8	19.8	20.3	19.5	19.5	19.8	19.1	19.4	19.3	19.5	19.9	19.9	20.3	20.3
15	20.7	21.8	22.2	22.4	22.8	22.8	20.9	19.2	23.8	31.7	33.1	33.8	30.6	55.7	30.4	29.2	28.9	28.9	28.6	29.1	30.4	33.5	35.3	40.2
16	43.6	44.7	48.1	48.0	48.7	50.8	48.6	24.2	22.3	21.6	36.2	31.8	30.1	29.7	29.1	26.2	19.0	22.5	21.8	21.2	18.7	17.9	18.7	19.2
17	17.7	17.8	18.2	18.7	19.2	19.7	16.6	23.8	24.7	27.5	28.9	25.3	19.5	20.4	21.5	21.0	20.5	21.7	20.9	19.4	19.1	19.1	21.7	21.0
18	21.6	25.3	26.8	31.9	33.4	33.4	29.1	26.6	32.0	32.8	30.2	29.4	29.5	31.3	31.6	30.5	32.3	28.5	32.1	41.6	42.2	41.7	41.9	43.2
19	43.0	43.1	43.7	43.6	43.3	44.4	44.4	41.9	42.8	43.8	44.2	44.0	44.1	44.5	44.9	46.1	45.9	46.2	47.3	46.1	47.5	46.2	46.5	45.5
[illegible]	5.5	46.2	46.1	44.7	44.6	44.0	44.7	42.8	43.0	34.3	25.4	26.0	26.5	25.9	25.8	1.$	2279.0	26.5	26.9	42.0	43.0	43.6	43.7	43.1
21	41.9	41.2	40.6	39.9	39.3	39.4	38.1	37.3	37.1	32.2	38.4	38.3	38.7	39.1	38.4	39.4	38.9	38.6	38.7	38.9	38.5	39.0	38.6	38.2
22	38.5	38.0	37.9	37.2	37.4	37.0	32.9	32.7	36.4	37.2	37.0	37.4	38.5	39.9	49.7	58.3	54.8	58.9	60.6	61.1	60.4	71.0	61.6	61.7
23	61.1	62.0	63.0	64.7	63.5	59.8	56.8	57.6	55.3	53.8	59.6	60.3	56.1	67.2	65.7	58.6	54.9	49.7	57.5	59.9	61.0	63.3	65.7	68.5
24	69.6	70.4	69.6	54.6	37.4	71.3	75.8	72.3	64.2	60.3	61.2	63.1	62.8	58.6	53.4	53.3	50.9	54.0	56.2	58.4	56.5	49.6	54.3	55.8
25	42.4	41.9	32.9	27.6	35.3	14.9	36.5	43.8	50.0	50.9	51.4	51.6	51.2	51.6	51.7	52.1	52.7	54.4	54.8	54.6	55.3	56.1	56.7	54.9
26	54.9	54.1	54.2	53.0	48.4	53.6	47.5	51.6	51.2	51.8	50.8	51.6	51.9	52.3	51.4	52.1	54.3	54.1	52.0	53.1	52.6	52.3	50.7	50.8
27	50.3	51.4	50.9	51.2	51.3	50.6	49.8	50.3	49.2	42.2	25.8	23.5	16.5	20.2	25.5	24.9	27.6	30.0	28.1	29.2	26.0	31.8	29.6	34.2
28	36.0	35.7	37.1	36.4	37.0	34.9	30.5	32.1	32.8	31.2	32.9	33.1	32.5	32.3	29.7	26.5	26.4	24.8	25.7	27.1	28.1	28.7	27.3	26.5
29	27.1	28.6	27.8	27.1	26.6	27.8	26.9	25.3	29.4	30.0	28.3	24.6	22.5	23.9	22.7	29.6	25.3	26.5	25.6	25.5	25.8	26.9	27.3	28.2
30	29.2	29.2	25.7	24.6	24.4	25.3	23.6	22.6	27.7	1.$	32.3	1.$	30.2	30.3	33.5	33.5	33.7	32.6	32.5	32.6	39.1	33.9	34.8	35.3

VEOLIA
WATER

July 6, 2009

Re: Quarterly Report – Fluid Bed Incineration, Operation and Maintenance

To whom it may concern:

Please be aware the Carbon Monoxide (CO) analyzer was not working properly and was down for maintenance from 4/24 – 4/27/ 2009. The data from this period does not accurately reflect the quality of the air emissions from this time frame. The unit was repaired and CO data returned to its correct level.

If any questions arise during the review of this report, please do hesitate to contact me at 504-277-5400.

Sincerely,

K. Servat

Kevin Servat
Project Manager
Veolia Water, New Orleans

Veolia Water North America Operating Services, LLC
6501 Florida Avenue, New Orleans, LA 70117
Tel: 504.277.5400 • Cell: 504.628.2628
www.veoliawaterna.com

Monthly CO CEM Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Hourly CO Averages

Day	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
[illegible]	0.3	0.2	0.0	6.6	29.1	0.8	2.7	0.3	3.9	0.8	0.9	0.1	0.3	0.1	1.3	4.0	3.4	2.4	6.3	9.5	5.5	1.6	4.4	1.4
2	4.7	2.4	1.5	0.8	0.7	1.2	4.0	2.2	2.0	2.9	2.0	2.0	0.2	2.4	5.3	20.0	16.1	13.3	7.9	17.8	26.4	5.7	6.3	20.3
3	64.9	51.0	0.1	0.2	0.0	0.0	0.1	0.0	0.0	19.5	9.9	4.3	2.2	4.0	4.2	7.7	7.3	5.0	3.9	16.9	14.0	1.6	17.3	0.3
4	0.5	0.2	0.0	0.1	21.5	1.3	0.1	0.4	1.4	0.8	1.3	0.9	0.8	0.6	1.0	1.2	0.7	1.1	1.2	7.1	0.2	1.1	1.2	1.2
5	1.4	1.2	1.3	1.3	1.2	1.2	1.2	1.3	1.3	1.3	1.4	1.4	1.3	1.3	1.2	1.2	1.3	1.6	1.6	1.7	1.8	1.7	1.6	1.5
6	1.5	1.5	1.4	1.4	1.5	1.4	1.3	1.5	1.5	1.6	1.6	1.7	1.6	1.6	1.6	1.7	45.8	1.7	1.4	1.5	1.7	1.6	1.6	1.7
7	1.7	1.7	1.7	1.7	1.7	1.8	1.8	1.8	1.8	1.9	1.8	12.0	1.5	2.0	2.0	2.0	1.9	1.9	1.9	2.0	2.3	2.5	2.3	2.4
8	2.8	2.9	2.3	2.3	2.4	2.5	2.2	3.0	3.2	3.2	2.4	2.1	1.5	2.8	4.1	5.9	9.0	5.7	4.3	9.0	10.7	12.5	14.4	13.8
9	15.3	17.5	19.1	19.6	17.2	15.8	13.5	6.6	3.1	3.0	2.8	1.3	0.9	0.0	0.4	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	2.4	0.3	0.2	0.2	3.8	42.2	0.0	0.0	0.0	0.0
13	0.1	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.3	2.6	0.1	0.2	0.2	0.2	0.1	0.1	0.4	0.7	0.2	0.5	0.6	0.2	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.0	0.0	0.0	0.0	0.0	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.4	0.0	1.5	0.0	0.0	0.0	0.0	1.5	26.1	13.0	1.0	9.2	65.6	92.0	48.2	33.5
17	122.9	165.7	76.1	84.0	0.1	0.1	29.2	12.6	11.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20	0.0	0.0	2.6	36.9	85.5	123.3	0.0	0.0	0.0	80.5	123.0	120.7	133.0	195.6	224.4	119.3	38.7	21.1	0.4	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	50.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	137.3	0.0	0.0	0.0	20.0	498.1	127.3	92.0	0.3	327.9	4.2	0.0	0.0	0.0	0.0	0.0
23	0.0	0.0	0.0	0.0	0.0	0.0	15.5	0.4	99.8	0.0	0.0	0.1	0.0	0.0	0.0	0.0	3.6	42.4	17.1	76.2	65.8	25.1	31.8	72.5
24	138.3	222.9	210.9	94.2	380.1	212.4	384.6	227.8	48.5	2.6	3.7	158.0	262.6	282.5	347.0	403.5	466.4	80.7	0.0	2.1	51.5	162.8	21.6	2.0
[illegible]	98.9	271.5	407.0	494.4	257.0	13.6	157.0	134.3	68.9	165.0	127.3	116.9	267.3	398.6	493.1	382.8	401.7	493.6	500.0	498.9	500.0	500.0	500.0	500.0
26	500.0	499.9	491.9	499.6	331.6	31.8	33.7	33.2	0.0	0.1	0.4	6.0	88.0	282.1	470.6	499.3	497.9	481.9	464.0	494.6	499.4	499.9	500.0	500.0
27	500.0	499.7	485.0	499.9	497.4	464.3	500.0	497.5	256.6	67.2	0.2	2.3	9.1	4.0	1.4	1.5	1.6	2.1	1.7	1.7	1.6	1.9	1.8	1.9
28	2.0	2.1	2.2	2.2	2.2	2.1	2.0	2.0	1.9	1.9	2.0	2.2	2.0	2.2	2.5	2.6	2.2	2.0	1.9	2.1	2.1	2.3	2.2	2.0
29	1.8	1.9	1.8	1.7	1.7	1.8	1.9	1.6	1.5	2.5	2.0	1.7	1.4	1.7	4.0	2.3	2.6	2.4	2.6	2.5	2.5	2.8	3.0	2.8
30	3.1	3.3	4.4	5.3	4.3	5.0	3.8	5.0	2.6	1.7	3.1	2.9	5.1	3.8	3.2	3.3	3.4	3.3	3.1	3.2	6.8	3.5	3.4	3.5

Monthly NOX CEM Report

New Orleans - East Bank WWTP
Apr 01, 2009

VEOLIA WATER

Hourly NOX Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	39.3	38.6	37.1	48.3	28.8	50.2	35.1	38.8	37.3	36.4	34.0	14.3	37.8	34.6	39.1	36.8	38.9	32.5	36.5	36.7	37.4	35.8	39.2	33.2
2	39.1	43.0	39.8	37.8	31.1	33.9	33.9	36.7	34.5	33.9	34.5	29.5	22.3	32.8	37.9	44.0	47.4	43.1	39.1	42.9	63.6	41.6	39.8	47.8
3	36.8	41.5	36.3	35.0	35.3	35.5	28.5	30.9	29.6	33.9	49.5	34.1	34.0	33.6	32.3	43.8	36.6	36.8	27.1	43.9	37.0	37.7	45.0	29.6
4	33.6	34.2	34.5	25.4	44.6	43.0	26.6	44.2	14.2	31.1	17.9	25.6	30.9	34.6	25.1	18.7	39.4	19.4	21.0	23.7	53.6	21.7	15.7	13.7
5	12.6	11.8	15.3	14.1	11.5	8.3	6.2	3.9	3.7	3.6	3.5	3.6	3.7	9.4	10.5	12.2	8.1	5.6	4.6	4.3	3.7	3.7	3.8	4.2
6	4.3	4.3	4.5	4.4	4.5	4.5	4.3	4.6	4.6	4.6	4.5	4.5	4.4	4.4	4.3	4.3	24.1	20.4	17.6	15.8	6.3	5.1	4.8	4.8
7	4.9	4.8	4.8	4.8	4.8	4.7	5.0	4.8	4.7	4.7	4.8	24.3	25.3	13.2	11.7	12.1	11.3	12.7	13.5	13.1	5.1	4.3	4.4	4.5
8	4.6	4.4	4.4	4.4	4.3	4.3	4.3	4.4	4.4	4.4	4.3	41.1	55.1	44.6	42.8	16.4	14.0	21.0	24.5	9.4	5.2	4.6	4.6	4.6
9	4.6	4.8	4.8	4.8	4.9	5.0	4.8	4.4	3.8	3.9	6.5	46.5	39.7	32.1	39.8	43.3	33.2	34.7	31.0	28.2	30.9	31.4	37.8	31.9
10	35.9	37.5	35.9	38.6	39.1	37.2	40.8	36.9	34.9	32.3	38.8	33.7	35.7	38.7	46.1	41.2	39.5	40.6	38.1	40.2	36.8	40.4	33.0	35.9
11	33.7	41.7	38.2	35.0	43.0	36.8	43.0	36.4	33.8	32.0	32.0	32.4	31.5	38.0	41.1	40.6	39.1	39.4	39.8	39.0	41.3	38.5	36.2	32.3
12	32.2	42.3	39.5	38.6	43.2	46.8	57.2	55.1	49.1	44.9	46.8	53.7	46.4	48.8	18.1	46.5	45.7	50.5	10.1	34.6	20.0	20.9	18.8	20.2
13	17.7	21.2	22.0	22.6	23.5	24.3	22.3	23.9	24.0	14.3	32.2	46.2	41.4	42.9	43.5	38.2	35.4	39.1	37.5	36.0	39.0	34.1	36.3	31.8
14	31.5	37.1	34.8	38.1	41.0	38.7	41.9	9.2	3.2	3.2	3.1	3.1	2.9	3.1	3.2	3.2	3.4	3.3	3.3	3.2	3.0	3.1	3.0	3.0
15	3.0	2.8	2.5	2.4	2.5	2.4	2.8	3.3	24.8	32.5	28.9	28.2	32.1	30.8	33.7	36.1	34.0	37.2	34.5	35.8	32.5	35.3	39.4	42.3
16	43.9	42.5	40.9	43.4	42.9	40.0	34.5	20.8	2.6	6.4	39.3	42.6	41.4	44.3	44.1	28.9	0.4	0.2	0.1	0.1	2.2	2.6	1.0	0.6
17	2.1	1.9	2.1	1.5	0.0	0.0	0.4	6.4	29.0	66.0	62.2	62.5	56.1	55.5	54.7	52.5	52.8	54.2	57.3	56.9	54.8	51.8	49.5	49.7
18	49.3	46.7	45.1	38.3	43.4	45.3	56.4	46.5	40.4	39.1	43.8	49.8	47.3	53.8	46.7	50.8	48.8	49.1	47.7	46.4	44.8	44.4	41.9	41.2
19	40.4	38.2	35.5	35.6	36.8	30.8	29.6	34.8	36.3	35.8	37.2	39.4	39.4	45.7	47.7	57.1	54.5	57.0	61.9	55.8	63.3	48.0	52.1	48.8
[illegible]	9.4	57.0	59.8	53.5	50.2	54.7	52.5	45.8	46.7	35.9	3.0	2.9	3.0	3.3	3.2	122.0	136.9	3.4	3.5	47.6	56.2	49.2	44.6	47.0
21	47.1	47.0	46.8	43.6	41.7	43.8	39.9	43.5	46.6	34.2	63.9	61.8	64.0	63.7	62.9	62.8	66.5	63.5	65.4	65.2	57.5	54.6	53.0	50.9
22	53.1	52.6	53.2	50.9	44.8	43.4	45.9	44.9	46.0	50.5	52.8	56.6	59.5	59.4	58.1	39.0	39.2	42.6	43.2	43.0	37.9	44.9	45.9	36.4
23	35.4	39.2	38.6	41.3	41.9	37.0	37.9	38.2	35.9	27.9	31.3	37.5	42.7	38.9	44.7	33.2	34.0	27.7	29.6	30.9	31.3	32.1	35.3	37.9
24	40.5	38.0	40.3	37.1	30.0	41.9	45.6	40.6	37.5	31.8	35.0	36.7	36.1	36.9	27.0	33.3	28.2	28.6	32.0	36.8	39.7	34.7	32.7	31.3
25	35.8	33.6	28.5	21.2	21.9	2.7	9.9	27.2	27.5	27.1	28.2	28.1	29.6	30.8	31.5	28.3	31.2	32.0	34.0	34.2	33.3	30.8	31.2	28.3
26	30.2	30.0	28.5	25.0	27.9	26.1	27.4	25.4	27.3	31.5	29.4	34.4	39.4	37.2	40.9	35.6	38.0	37.1	35.9	35.8	34.2	32.1	33.0	35.5
27	30.9	30.6	34.7	30.2	33.2	34.3	31.2	32.6	34.3	37.5	37.9	41.5	24.6	39.5	53.3	50.9	52.7	67.6	44.0	42.5	46.5	44.0	44.7	33.6
28	36.2	35.7	34.0	34.2	36.5	38.7	38.2	39.8	34.4	38.5	42.2	37.0	32.1	35.3	37.7	36.0	39.1	37.8	38.0	37.6	32.0	31.0	32.2	30.9
29	27.8	27.6	29.0	29.2	28.6	33.6	32.1	31.4	36.9	39.4	42.5	51.3	51.9	55.5	50.9	60.0	57.6	56.1	63.2	57.1	57.2	52.4	51.6	50.1
30	46.9	47.3	52.8	51.4	56.2	53.2	53.2	54.0	48.8	115.3	33.5	68.6	41.8	40.6	44.4	41.7	40.5	39.6	41.2	40.0	31.5	36.4	34.3	34.3

Monthly Exceedence Report

New Orleans - East Bank WWTP
May 2009

Date/Time	Description	Duration	Peek Value	Operator	Reason
05/07/2009 11:45:02	CO > 100 ppm	27:06:03	500.00	Jawanda Trimont	Adjusting Feed Rate
05/13/2009 12:35:02	CO > 100 ppm	04:15:02	138.90	Jawanda Trimont	Adjusting Feed Rate
05/28/2009 06:07:04	CO > 100 ppm	00:27:57	236.70	Steven J Robinso	Adjusting Feed Rate
05/28/2009 06:38:05	CO > 100 ppm	00:05:59	187.50	Steven J Robinso	Adjusting Feed Rate
05/28/2009 07:27:02	CO > 100 ppm	00:59:00	147.90	Carl Kelly	Adjusting Feed Rate

Monthly O2 CEM Report

New Orleans - East Bank WWTP
May 01, 2009

VEOLIA WATER

Hourly O2 Averages

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	15.3	15.6	15.5	15.4	15.5	15.9	14.7	15.4	15.1	15.2	16.3	15.4	15.1	15.1	15.1	15.0	15.0	15.4	15.4	15.7	15.7	16.0	16.1	16.1
2	15.9	15.9	15.7	15.6	16.3	16.3	18.6	16.7	15.3	15.1	14.9	15.1	15.0	15.0	15.1	15.0	15.5	15.5	15.4	15.5	15.5	15.6	15.7	15.6
3	17.8	16.5	15.3	15.3	15.4	15.4	15.2	15.5	15.3	15.2	15.4	16.0	15.6	15.2	15.3	15.2	15.1	15.7	15.7	15.8	14.8	15.6	15.5	15.5
4	15.5	15.6	17.4	17.0	17.0	16.9	17.0	16.7	16.6	16.4	16.4	15.6	13.4	14.1	13.9	13.8	13.7	13.3	13.4	13.7	14.0	14.1	14.0	13.8
5	13.7	13.1	14.0	13.5	13.3	13.7	13.4	13.4	13.2	13.3	13.6	15.6	15.7	15.4	15.3	15.4	15.6	17.9	18.1	16.8	16.5	16.7	16.5	16.7
6	16.8	17.1	16.9	16.7	16.7	16.7	16.5	16.4	15.4	15.4	15.8	16.3	17.2	15.7	13.1	12.9	13.1	12.6	13.1	14.0	13.5	13.3	13.6	13.3
7	12.8	13.5	12.9	12.9	13.2	13.6	13.3	13.2	12.2	11.9	13.5	11.1	20.1	20.9	20.9	20.9	20.9	20.9	20.9	20.9	20.9	20.9	20.9	20.9
8	20.9	20.9	20.8	20.8	20.8	20.8	20.9	20.9	21.0	20.7	21.0	21.0	21.0	21.0	21.0	16.7	15.4	11.6	11.4	11.6	11.6	11.9	11.9	12.1
9	11.9	13.1	11.3	11.2	12.9	11.7	11.4	11.8	12.2	12.2	12.2	12.1	12.1	12.0	12.1	12.0	12.1	12.1	12.0	12.3	12.1	12.1	12.0	12.4
10	12.5	13.6	12.8	12.8	12.6	13.0	12.8	12.3	12.8	13.4	13.3	13.3	13.3	13.0	13.2	13.1	13.0	13.0	13.0	13.0	13.0	13.5	12.8	12.4
11	12.9	12.5	12.9	13.2	13.5	13.1	13.1	12.7	13.3	12.7	12.9	13.4	12.2	12.6	16.8	13.6	12.5	12.7	12.9	14.1	13.9	13.3	15.2	14.3
12	12.5	15.3	15.3	15.0	14.7	14.9	14.7	14.2	13.5	13.2	12.8	12.2	12.8	13.7	13.1	13.5	13.2	13.4	13.7	13.5	14.5	15.7	13.3	13.6
13	13.6	13.8	13.7	13.6	13.4	12.9	13.2	14.3	12.6	13.5	15.0	15.0	17.8	20.9	20.9	20.9	20.9	19.3	16.2	15.5	15.8	16.7	16.6	16.8
14	16.8	16.7	16.4	16.6	16.8	16.8	16.5	16.5	16.5	16.5	15.5	14.4	15.1	14.6	14.0	13.1	13.5	13.9	13.2	14.1	14.3	14.4	13.2	14.9
15	15.7	15.4	15.4	15.3	15.2	15.5	15.6	15.7	15.8	15.5	15.5	15.5	15.4	16.0	15.5	15.1	15.4	14.7	14.9	15.1	15.2	14.9	15.2	15.1
16	15.4	15.4	15.3	15.3	15.4	15.3	14.3	14.5	14.6	14.9	15.0	15.0	14.9	14.7	14.5	14.4	15.4	14.2	15.0	15.4	14.9	14.8	15.4	15.9
17	15.3	15.6	16.0	16.2	16.2	15.8	15.5	15.3	15.9	16.1	15.7	15.6	15.1	15.4	15.3	14.5	15.1	15.2	15.9	15.4	15.6	15.8	15.9	16.2
18	16.5	16.8	17.0	17.0	17.1	17.0	17.2	17.1	17.1	17.1	16.4	16.0	18.8	18.6	18.6	14.8	14.5	14.4	14.2	15.3	14.8	15.8	15.9	15.7
[illegible]	15.3	16.4	15.9	16.1	16.1	15.9	15.7	16.5	15.8	20.9	17.8	13.6	13.4	13.7	13.1	13.5	13.5	12.9	12.8	13.0	13.5	13.6	13.8	13.9
20	16.9	16.3	17.0	16.7	16.6	16.7	16.4	17.7	18.1	18.9	18.7	18.9	18.5	18.2	18.1	17.7	18.1	17.6	17.6	18.1	18.2	18.4	18.2	18.2
21	18.5	18.6	18.7	18.6	18.8	18.3	18.8	18.4	18.3	17.9	17.8	17.4	17.3	17.5	17.6	18.2	17.8	18.1	18.1	18.2	18.2	18.3	18.5	18.3
22	18.4	18.3	18.4	18.3	18.5	18.5	18.4	18.2	18.4	18.1	17.7	17.5	17.4	17.2	16.8	16.4	15.2	10.2	13.3	12.5	7.5	11.3	10.3	10.0
23	9.8	10.0	9.9	13.2	9.9	10.2	10.4	10.2	11.8	11.4	11.7	11.2	11.3	11.7	12.1	12.0	12.2	12.2	12.2	12.5	12.1	14.6	13.2	12.8
24	12.8	13.0	13.4	13.0	13.5	13.8	13.3	13.9	13.3	13.3	13.2	13.2	13.9	13.3	16.9	17.8	16.6	20.9	20.6	19.9	20.2	20.3	20.2	20.1
25	20.2	20.4	20.6	20.4	20.2	20.2	20.2	20.2	20.5	20.0	20.6	20.2	18.1	14.8	11.1	12.4	12.6	12.6	12.7	12.7	11.8	12.9	10.0	13.4
26	13.9	13.6	13.9	13.7	13.7	13.6	13.7	14.0	14.2	13.0	14.2	13.1	12.6	13.0	12.6	12.7	12.4	12.3	12.4	12.1	12.1	11.7	11.6	12.2
27	12.1	17.3	14.6	14.0	14.3	13.7	14.0	13.5	14.2	14.3	12.8	13.5	13.0	13.1	12.7	13.4	13.8	15.1	14.5	13.1	12.9	12.7	12.3	12.3
28	12.7	12.7	12.6	12.4	12.4	12.4	15.7	21.1	19.2	17.7	17.2	12.5	12.1	12.5	12.8	12.4	12.4	12.4	12.7	15.0	12.4	13.2	12.5	12.5
29	12.8	13.0	13.0	13.2	13.2	13.2	13.2	13.5	13.1	13.3	13.4	13.2	13.2	13.3	13.4	13.4	13.3	13.4	13.4	13.4	12.5	12.7	12.8	12.7
30	13.1	13.0	13.1	13.1	12.9	13.1	12.7	12.6	14.4	13.3	13.2	13.8	13.1	12.9	12.3	12.6	13.1	12.6	13.2	12.7	12.6	12.2	12.2	12.5
31	12.8	13.2	14.0	13.3	13.1	12.9	12.9	13.6	13.1	13.9	13.5	13.8	13.8	13.7	13.2	13.3	13.5	13.6	13.2	13.7	13.7	13.8	13.1	13.7

Monthly O2 Analyzer Report

New Orleans - East Bank WWTP
May 01, 2009

VEOLIA WATER

Hourly O2 Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	9.9	10.0	10.0	9.9	9.9	10.4	10.2	10.3	10.4	10.2	11.4	10.5	10.3	10.3	10.4	10.3	10.3	10.6	10.7	10.9	10.8	11.0	11.0	10.9
2	10.6	10.6	10.4	10.2	11.1	11.0	15.4	12.0	10.2	10.1	10.0	10.0	10.1	10.1	10.1	10.1	10.3	10.5	10.3	10.1	10.3	10.3	10.3	10.2
3	13.3	12.2	11.0	10.7	10.7	10.6	10.4	11.2	10.6	10.4	10.4	10.6	10.5	10.4	10.5	10.4	10.5	10.4	10.6	10.4	10.5	10.6	10.4	10.4
4	10.3	10.5	13.1	12.6	12.5	12.5	12.6	12.5	12.2	12.2	12.0	10.9	8.0	8.3	8.7	8.5	8.6	8.6	8.5	8.7	8.8	9.0	9.0	8.7
5	8.6	8.3	8.6	8.3	8.4	8.7	8.8	9.0	8.0	7.9	8.0	10.6	10.9	10.6	10.6	10.5	10.7	13.9	14.0	12.0	11.5	11.7	11.4	11.6
6	11.6	11.9	11.7	11.4	11.4	11.5	11.5	11.4	10.3	10.0	10.2	11.0	12.2	10.0	7.6	7.5	7.8	7.3	7.8	8.5	8.1	7.8	8.4	8.1
7	7.1	8.3	8.2	8.3	8.1	8.4	8.4	8.5	6.8	6.7	7.6	6.1	15.4	17.1	17.6	17.8	17.9	18.0	18.1	18.1	18.2	18.2	18.2	18.2
8	18.2	18.3	18.3	18.3	18.3	18.3	18.5	18.7	18.7	18.6	18.7	18.6	18.6	18.6	18.6	12.4	11.7	7.1	6.8	7.7	7.9	8.3	8.2	8.5
9	8.1	9.4	7.8	7.3	9.0	7.8	7.8	7.8	8.0	7.9	7.9	7.8	8.0	7.9	7.8	7.7	7.7	7.7	7.6	7.8	7.7	7.8	7.8	8.0
10	8.0	9.2	8.4	8.3	7.9	8.1	8.3	8.2	8.1	8.4	8.3	8.5	8.3	8.0	8.5	8.5	8.4	8.4	8.2	8.0	8.2	8.8	8.4	8.4
11	8.4	8.3	8.5	9.0	9.3	8.7	8.6	8.7	8.8	7.5	8.2	8.5	7.1	7.5	12.4	8.6	7.8	7.9	8.1	8.9	9.0	8.0	9.9	8.9
12	7.0	10.9	10.7	10.5	10.4	10.7	10.2	10.2	8.9	8.5	8.0	8.2	8.0	9.1	7.9	8.1	8.4	8.4	8.6	8.2	9.1	10.4	7.3	8.4
13	8.4	8.4	8.3	8.2	8.0	7.7	8.1	9.4	7.4	8.2	10.3	10.2	13.3	17.2	16.8	17.1	18.0	15.4	11.0	10.0	10.2	10.6	10.6	10.8
14	10.8	10.7	10.5	10.7	10.5	10.8	10.9	11.1	11.0	11.2	9.9	8.7	9.8	9.3	8.0	8.0	8.5	8.6	8.5	9.0	9.5	9.3	7.4	9.6
15	11.1	10.5	10.5	10.6	10.6	10.9	10.9	11.5	11.3	10.8	10.7	10.8	10.6	11.4	10.5	10.3	10.5	9.3	9.7	10.0	10.0	9.9	10.2	9.8
16	9.6	9.5	9.5	9.5	9.3	9.3	8.9	9.3	9.3	9.2	9.2	9.2	9.1	9.1	9.0	9.0	10.0	8.8	9.9	10.4	9.5	9.8	9.8	9.8
17	10.0	10.1	10.0	9.9	10.4	10.4	10.4	10.3	10.1	10.3	9.8	9.7	9.6	9.4	10.0	9.9	10.1	9.3	10.3	11.1	11.2	11.3	11.6	11.8
18	11.8	11.9	12.0	11.8	12.1	12.1	11.9	12.7	12.4	12.1	11.5	10.8	13.8	14.6	14.6	8.6	8.8	8.7	8.5	10.0	8.4	9.6	9.9	10.0
19	9.3	11.1	10.0	10.1	10.3	10.4	10.4	11.5	10.6	9.8	9.6	9.4	9.1	9.1	8.9	9.1	9.0	8.9	8.8	9.0	9.6	9.7	9.8	9.7
20	13.2	12.6	13.2	12.9	12.9	12.9	12.6	13.1	13.3	15.0	15.0	15.0	14.6	14.4	14.4	14.3	14.7	14.3	14.6	14.6	14.7	14.6	14.5	14.5
21	14.5	14.5	14.5	14.5	14.5	14.5	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.5	14.6	14.5	14.6	14.6	14.6	14.6	14.6	14.6	14.6
22	14.6	14.6	14.6	14.5	14.6	14.6	14.7	14.6	14.8	14.6	14.7	14.6	14.7	14.6	14.2	13.6	12.7	8.0	10.7	10.1	5.2	8.0	6.0	6.1
23	5.9	5.8	5.6	9.7	6.3	6.6	6.9	6.6	8.5	8.4	8.7	8.4	8.3	8.7	8.7	8.7	8.8	8.7	8.6	8.6	8.3	11.3	10.5	10.2
24	10.3	10.4	10.4	10.2	10.8	10.7	10.4	10.9	10.1	10.2	9.9	9.8	10.5	10.1	13.5	14.7	13.5	16.3	16.8	16.8	17.2	17.3	17.3	17.3
25	17.3	17.5	17.5	17.4	17.3	17.5	17.6	17.8	17.7	17.4	17.4	17.6	15.2	11.5	7.4	8.2	8.5	8.5	8.4	8.4	7.8	10.4	7.5	10.5
26	11.2	10.8	10.9	10.9	10.9	10.9	10.7	11.1	11.1	10.0	10.8	10.0	9.3	9.7	9.5	9.6	9.2	9.0	9.2	9.0	9.1	9.2	9.2	9.3
27	9.3	14.2	11.4	10.1	10.4	10.2	10.4	10.4	10.8	10.3	8.8	10.1	10.0	10.1	10.0	10.1	9.9	11.2	10.4	9.1	9.2	9.3	8.6	8.5
28	8.5	8.9	9.3	9.5	9.2	9.3	12.6	17.9	15.8	14.3	13.7	8.1	7.8	8.3	8.6	8.4	8.5	9.0	8.8	11.7	9.4	10.5	8.8	8.7
29	9.0	9.1	9.0	9.3	9.4	9.4	9.5	9.5	9.6	9.5	9.5	9.3	9.3	9.3	9.6	9.5	9.5	9.5	9.5	9.5	9.2	9.3	9.3	9.3
30	9.4	9.4	9.6	9.3	9.4	9.3	9.3	9.3	9.9	8.7	8.8	8.9	8.7	8.4	7.7	8.5	8.3	7.7	8.3	8.0	8.3	8.4	8.5	8.9
31	8.9	8.9	9.0	9.0	9.0	9.0	8.8	8.8	9.1	9.3	9.2	9.3	9.2	9.3	8.6	9.0	8.8	8.9	8.7	8.9	9.1	9.1	9.2	9.2

Monthly Moisture CEM Report

New Orleans - East Bank WWTP
May 01, 2009

VEOLIA WATER

Hourly Moisture Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	35.5	35.7	35.6	35.5	36.3	34.8	33.1	33.0	31.0	32.8	29.9	31.3	31.4	31.5	31.5	31.7	31.2	30.9	30.5	30.3	31.2	31.3	31.7	32.3
2	33.3	33.4	34.0	34.5	32.3	32.7	21.8	28.4	33.5	33.4	32.8	33.6	32.5	32.8	33.3	32.9	33.2	32.2	32.9	34.4	33.3	34.4	34.3	34.9
3	25.7	26.6	27.7	29.9	30.7	31.0	32.8	28.0	30.9	31.7	32.4	33.5	32.6	31.7	31.8	31.9	30.2	33.6	32.5	34.0	29.1	32.0	32.7	33.0
4	33.0	32.5	24.9	26.1	26.2	26.2	25.9	25.1	26.9	25.6	26.8	30.9	40.7	41.2	37.2	37.9	37.5	35.6	36.3	36.1	36.6	36.3	35.6	36.9
5	37.1	36.6	39.0	38.4	37.2	36.9	31.9	32.7	39.4	40.5	41.4	32.3	30.2	31.4	30.4	31.9	31.5	22.6	22.7	28.4	30.0	30.1	30.9	30.8
6	31.1	30.2	30.8	31.7	31.6	31.4	32.8	30.1	33.2	34.9	35.1	32.4	29.0	36.6	42.3	42.2	40.4	42.4	41.0	39.2	39.5	41.4	38.4	39.6
7	44.7	38.6	36.0	35.6	38.4	38.3	35.9	35.7	44.6	45.7	44.2	45.0	24.3	17.8	15.5	14.6	14.2	13.7	13.4	13.2	12.9	12.8	12.7	12.6
8	12.5	12.3	12.0	11.8	11.7	11.8	11.6	11.0	11.2	1.$	11.2	11.3	11.2	11.2	11.3	26.2	25.4	39.0	39.4	33.2	32.2	30.3	31.1	29.9
9	31.4	28.1	31.4	34.2	30.2	33.0	33.6	33.9	34.3	35.1	34.6	35.2	33.9	33.9	35.2	35.6	35.9	36.6	36.8	36.5	36.4	35.2	34.9	35.6
10	35.6	32.5	34.6	35.1	37.5	38.0	36.5	33.5	36.9	36.9	37.1	35.7	37.4	38.5	36.1	35.1	35.4	35.9	36.6	38.0	36.7	34.4	34.5	32.0
11	34.8	33.8	34.1	31.8	30.6	33.6	34.6	31.0	33.9	40.7	36.3	36.4	42.0	39.9	27.5	37.3	37.9	37.6	37.0	36.5	35.1	39.9	36.4	37.7
12	44.4	28.3	30.1	29.9	29.0	28.0	29.5	28.0	34.2	35.7	37.8	33.1	37.5	33.5	39.4	40.1	36.3	37.0	37.3	39.3	40.5	34.8	45.8	38.5
13	38.4	39.3	39.3	39.9	40.6	40.2	39.6	35.2	41.2	39.1	31.3	32.2	25.8	17.6	19.3	17.8	13.9	21.0	32.3	35.3	34.9	36.3	36.0	35.9
14	35.7	35.6	35.9	35.6	37.1	36.0	35.0	32.4	33.4	31.9	36.4	39.8	34.9	36.0	43.1	39.2	36.9	38.2	35.6	35.8	33.5	35.2	45.2	36.6
15	29.5	32.1	32.1	30.6	30.4	29.6	30.4	27.0	28.3	30.3	30.4	30.4	31.3	28.8	32.0	31.9	31.9	36.4	34.9	33.9	34.5	33.5	33.0	35.4
16	37.9	38.4	38.0	37.5	39.7	39.1	36.6	36.4	36.3	38.3	38.6	38.8	38.8	38.1	38.1	36.9	35.6	38.0	33.8	32.3	35.8	33.8	36.6	38.0
17	34.4	35.4	37.4	38.6	35.8	33.8	32.4	32.7	36.2	35.8	37.9	37.6	36.1	39.2	35.4	31.8	33.5	38.6	36.1	27.9	28.4	28.1	27.0	27.1
18	28.3	29.1	29.4	30.3	29.2	28.8	30.3	26.1	27.7	29.6	30.0	32.5	26.7	21.2	21.7	42.0	39.5	39.5	40.1	35.0	43.1	40.4	37.9	36.2
[illegible]	39.5	32.5	37.1	37.4	35.9	34.8	35.3	30.4	32.9	51.9	43.4	1.$	1.$	32.9	30.9	32.7	33.0	30.6	30.6	30.2	28.7	28.4	28.7	29.9
20	22.0	22.3	22.3	22.8	22.3	22.3	23.2	25.8	26.7	20.9	19.7	20.2	21.4	20.9	20.7	19.0	18.9	18.3	17.0	19.2	19.6	20.4	19.9	20.3
21	21.4	21.7	22.4	22.3	22.7	20.8	22.2	19.9	19.7	17.7	17.2	15.5	15.4	16.1	17.1	19.7	1.$	19.8	19.5	19.8	19.9	20.1	20.7	20.3
22	20.7	20.0	20.8	20.7	21.1	21.3	20.3	20.0	19.5	19.2	16.9	16.4	15.7	14.7	15.6	17.1	17.4	22.2	19.7	19.7	31.6	31.4	41.4	38.6
23	39.8	41.2	43.1	27.4	36.0	34.5	34.7	34.7	27.8	26.3	25.4	25.2	26.5	26.1	27.6	27.8	27.9	28.9	30.1	31.1	31.3	22.9	20.5	20.0
24	19.2	19.4	21.9	21.6	20.2	22.4	21.1	21.6	24.0	23.2	25.4	25.2	24.7	24.3	20.1	17.8	18.7	21.8	18.1	15.0	14.6	15.2	14.5	14.0
25	14.0	14.1	15.0	14.7	14.2	13.3	12.7	12.3	13.8	13.0	15.1	13.2	17.2	22.0	33.3	34.1	32.1	32.6	33.7	33.4	33.3	19.5	25.6	21.7
26	19.4	20.2	21.0	20.2	20.1	19.5	21.1	20.6	21.9	1.$	24.3	23.6	25.6	25.2	25.0	24.7	25.5	26.9	25.9	25.5	24.7	21.1	20.5	24.3
27	22.7	18.2	22.0	27.9	27.5	25.3	25.0	23.1	23.7	27.9	31.1	25.0	22.7	22.6	21.1	24.0	28.1	26.4	28.6	30.4	28.7	27.0	30.1	31.0
28	33.0	29.7	26.0	23.6	25.8	24.8	21.6	14.9	17.9	19.1	20.9	35.2	35.5	33.9	33.1	31.9	31.7	27.8	30.2	22.1	24.4	21.1	29.6	30.3
29	29.6	29.4	30.7	29.5	28.1	28.3	28.4	29.4	26.3	28.3	28.9	29.8	29.6	29.7	28.6	29.1	28.6	29.4	29.2	29.1	26.5	26.7	27.3	27.0
30	28.3	27.5	27.3	28.8	27.4	29.3	27.5	25.6	31.4	34.1	33.4	35.5	33.6	34.4	37.0	32.9	37.0	38.7	37.4	36.9	34.0	31.6	30.3	28.9
31	30.0	32.6	35.3	32.2	31.2	30.3	30.4	35.2	30.8	32.9	31.4	32.8	32.9	32.2	34.5	32.1	34.6	34.0	33.9	34.5	33.4	33.5	30.2	32.9

Monthly CO CEM Report

New Orleans - East Bank WWTP
May 01, 2009

VEOLIA WATER

Hourly CO Averages

Day	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
[illegible]	3.4	3.6	3.4	3.3	3.5	3.5	2.9	3.0	2.7	2.9	3.6	3.0	2.8	2.8	2.9	2.9	2.7	2.8	2.8	2.9	2.9	3.0	3.1	3.1
[illegible]	2.9	3.0	2.9	2.9	3.7	3.6	8.9	9.8	2.7	2.6	2.6	2.7	2.6	2.6	2.7	2.6	2.8	2.6	2.6	2.8	2.6	2.6	2.7	2.7
3	7.6	6.2	2.0	2.1	2.2	2.1	2.1	2.4	2.0	2.0	2.2	2.5	2.3	2.0	2.1	2.1	2.0	2.3	2.3	2.4	1.8	2.2	2.2	2.1
4	2.2	2.2	3.8	3.0	2.9	2.9	2.9	2.6	2.8	2.6	2.6	3.5	2.7	2.6	2.4	2.4	2.4	2.1	2.1	2.1	2.2	2.2	2.2	2.2
5	2.2	2.1	2.4	2.3	2.2	2.3	2.1	2.0	2.3	2.3	2.3	2.3	2.0	2.0	1.8	1.9	2.1	5.4	6.5	2.3	2.0	2.2	2.1	2.3
6	2.3	3.1	2.9	2.6	2.5	2.6	2.3	2.1	2.0	2.2	2.5	3.0	4.1	3.0	3.5	2.7	2.1	2.5	2.5	1.8	3.0	2.8	1.9	18.6
7	7.5	2.2	1.8	1.7	1.9	1.9	1.5	1.6	21.0	53.1	6.6	4.3	144.0	196.4	181.6	196.3	189.7	196.0	198.0	197.1	205.0	202.3	209.3	201.6
8	207.2	184.8	114.9	101.7	102.9	128.5	203.6	206.7	417.7	453.4	500.0	500.0	500.0	500.0	496.5	28.3	12.8	1.4	1.4	1.2	1.0	0.9	1.1	0.9
9	1.1	1.2	1.9	1.7	1.6	1.2	1.2	1.2	1.1	1.2	1.2	1.2	1.1	1.0	1.1	1.1	1.1	1.0	1.1	1.0	1.0	1.0	1.0	1.0
10	0.9	1.1	1.1	0.9	1.1	1.0	0.9	0.9	1.0	0.9	0.9	0.8	0.9	1.0	0.9	0.9	0.9	0.8	0.8	1.0	0.8	0.9	0.7	0.7
11	0.8	0.8	0.8	0.8	0.8	1.0	0.7	0.7	1.9	3.6	1.0	0.9	1.9	1.5	12.0	1.0	1.0	1.0	0.8	0.6	0.5	2.2	4.5	0.8
12	5.5	1.8	0.5	0.5	0.5	0.5	0.4	0.5	0.9	1.0	2.2	1.9	1.8	5.2	2.0	1.4	0.8	1.0	0.7	1.1	24.4	9.4	5.2	0.9
13	1.0	1.1	1.0	1.0	1.6	1.3	3.0	6.5	4.6	2.6	1.1	1.2	23.7	137.0	138.5	134.3	129.6	79.4	2.3	1.4	1.4	1.8	1.7	1.8
14	1.8	1.7	1.8	1.9	2.2	2.0	1.5	1.4	1.6	1.4	1.2	1.5	0.8	0.9	2.5	2.6	1.2	1.3	1.2	1.0	0.8	0.9	6.1	3.3
15	1.9	1.5	1.5	1.5	1.6	1.6	1.4	1.5	1.4	1.3	1.3	1.3	1.3	1.7	1.3	1.1	1.3	1.3	1.1	1.1	1.1	1.1	1.1	1.2
16	1.3	1.4	1.4	1.4	1.6	1.5	1.8	1.5	1.3	1.4	1.5	1.7	1.5	1.5	1.5	1.2	2.2	2.1	0.9	0.8	0.9	0.9	1.1	1.1
17	0.9	1.0	1.2	1.3	1.3	1.3	1.3	1.2	1.3	1.2	1.2	1.2	1.1	1.5	2.7	1.2	1.0	1.7	2.8	1.2	1.2	1.3	1.3	1.4
18	1.6	1.8	2.0	2.0	2.0	2.1	1.9	2.2	2.0	1.9	1.6	1.3	11.2	8.1	8.4	3.5	1.8	2.0	2.0	2.2	2.6	3.6	1.3	1.1
19	1.4	1.6	1.1	1.1	0.9	0.8	0.8	1.4	17.9	0.3	0.4	15.8	1.3	1.1	0.7	0.4	0.5	0.4	0.1	0.0	0.0	0.0	0.0	0.0
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.5	26.6	54.3	26.4	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.9	6.0	2.5	2.7	4.3	1.7	6.4	1.0	0.0	0.0
23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0
24	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.8	30.4	0.0	7.1	0.0	0.0	0.0
[illegible]	0.0	0.0	19.9	9.7	0.0	0.0	0.0	0.4	9.2	0.0	18.7	0.0	47.8	0.0	1.4	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.5	0.0
[illegible]	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.5	0.0	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
27	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
28	0.0	0.0	0.0	0.0	0.0	0.0	66.0	182.6	123.2	12.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
29	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0
31	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Monthly NOX CEM Report

New Orleans - East Bank WWTP
May 01, 2009

VEOLIA WATER

Hourly NOX Averages

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	37.0	36.5	33.9	35.1	36.5	30.5	27.3	34.9	36.1	36.5	41.0	43.2	43.9	42.4	44.1	45.1	48.4	43.8	45.6	41.6	41.3	40.4	40.6	37.8
2	35.7	39.0	35.2	37.7	35.2	39.9	42.4	35.0	36.2	41.0	42.1	42.1	45.5	44.2	45.1	43.0	40.3	36.0	37.3	38.6	37.2	33.7	33.8	34.4
3	38.2	39.6	36.8	35.4	32.8	32.8	36.7	35.2	32.5	33.1	35.6	30.7	32.9	35.3	35.2	36.4	35.9	30.0	31.5	29.8	36.1	32.8	32.6	31.9
4	31.5	34.2	50.2	47.6	47.2	47.5	47.4	49.5	55.4	57.4	53.1	40.4	54.7	50.0	58.1	59.4	60.1	58.4	63.6	57.8	58.6	54.4	59.5	55.1
5	55.4	65.9	54.5	59.3	62.0	61.8	57.3	57.7	51.2	51.5	44.6	47.6	47.2	49.1	50.0	49.9	51.0	40.1	25.7	49.3	46.7	43.1	41.3	41.5
6	39.6	41.0	40.9	42.5	41.4	41.8	36.9	42.5	46.6	50.1	47.0	48.7	46.4	42.6	38.8	36.4	35.7	39.5	40.8	34.7	34.9	38.0	34.6	34.6
7	43.7	33.3	35.2	36.3	32.7	32.8	32.8	33.4	35.7	47.0	35.5	36.8	7.9	0.4	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
8	0.2	0.2	0.5	0.7	0.5	0.5	0.4	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	10.6	28.5	43.6	41.7	37.0	32.8	28.9	30.9	28.0
9	33.9	30.8	34.0	39.7	32.8	32.4	32.9	31.8	30.5	30.4	31.5	33.9	32.3	32.5	33.8	34.0	34.6	33.9	34.3	32.0	33.6	31.9	35.7	33.7
10	32.0	32.6	29.3	30.0	33.4	31.7	31.9	32.6	30.4	29.2	28.6	30.3	30.1	37.3	31.4	31.5	31.7	31.2	32.2	34.3	34.1	31.1	32.4	32.1
11	33.5	34.0	33.3	33.1	33.6	31.9	29.4	31.4	41.3	40.3	38.7	31.0	40.8	39.1	44.3	36.2	39.6	42.4	40.0	28.7	30.0	36.2	39.6	30.2
12	44.7	42.3	25.4	29.0	33.4	29.8	28.4	29.8	33.8	35.1	37.7	37.9	35.7	51.8	29.9	26.2	28.4	24.6	28.3	24.0	34.1	37.1	35.4	28.1
13	28.8	26.8	26.4	24.0	23.5	25.3	31.4	39.7	29.4	31.5	37.3	30.6	23.7	0.1	0.1	0.1	0.1	15.6	50.0	49.6	48.6	38.1	39.0	37.7
14	38.1	40.0	43.4	39.8	39.5	38.5	37.9	37.5	35.6	37.5	36.8	39.7	30.8	31.4	32.3	35.2	32.3	32.6	34.7	30.9	27.3	28.2	45.7	33.2
15	32.8	36.2	36.9	35.3	37.4	37.0	32.9	36.0	32.6	33.4	35.3	33.0	32.5	35.5	36.3	36.7	34.2	40.3	37.2	34.2	32.7	37.8	32.2	31.5
16	30.6	30.4	31.2	31.6	31.8	31.2	39.4	28.0	27.5	30.0	33.7	33.2	33.7	35.3	32.3	31.2	44.1	44.8	39.2	26.8	35.8	38.7	29.3	25.9
17	28.0	25.6	25.9	30.3	32.9	36.2	31.7	35.1	32.9	29.7	29.9	33.8	36.9	33.7	45.1	41.2	34.6	32.6	41.1	37.7	36.2	37.3	40.1	43.1
18	43.2	43.7	43.5	45.9	45.2	44.4	48.9	47.3	46.4	39.4	35.8	31.4	18.2	18.4	13.2	38.3	45.2	39.2	33.4	38.5	31.3	37.8	30.2	30.7
19	41.3	33.4	32.8	29.3	31.2	33.3	33.4	31.8	30.0	5.9	16.1	37.0	43.7	39.5	39.4	40.6	39.9	38.3	40.8	34.6	31.0	29.4	28.4	27.1
20	52.5	55.8	50.0	53.9	57.9	57.8	51.8	47.0	45.0	15.9	3.1	2.7	2.9	3.4	3.5	3.9	3.4	3.9	3.8	3.3	3.2	3.0	3.3	3.2
21	2.9	2.8	2.7	2.8	2.6	3.1	2.8	3.2	3.3	3.8	3.9	4.2	4.3	4.0	3.9	3.2	3.4	3.5	3.5	3.4	3.5	3.5	3.3	3.4
22	3.4	3.5	3.3	3.4	3.2	3.2	3.6	3.6	3.5	3.7	4.1	4.4	4.5	4.7	11.0	25.3	33.2	38.7	43.4	40.2	60.5	54.1	68.2	66.8
23	65.8	61.3	60.4	41.9	72.4	70.8	65.3	68.9	39.9	40.1	50.1	47.6	49.6	49.3	43.5	39.9	37.6	35.1	31.5	30.6	32.6	43.1	44.1	41.8
24	41.2	38.9	36.9	41.7	40.4	36.4	33.8	36.5	35.6	27.1	34.9	51.7	32.0	26.0	42.2	20.1	19.4	1.5	0.8	1.4	1.2	1.0	1.2	1.2
25	1.3	1.1	0.7	0.9	1.1	1.2	1.5	1.2	0.7	1.1	0.7	1.1	9.6	27.5	35.8	33.0	32.5	32.1	29.3	29.2	33.3	38.3	45.8	46.6
26	28.4	31.8	28.7	29.4	32.2	28.9	32.5	26.8	28.8	27.3	34.4	37.2	35.1	38.1	37.5	36.6	35.0	33.1	36.6	32.2	32.3	34.6	33.6	30.5
27	29.1	35.6	34.9	30.4	27.3	31.1	28.6	29.2	31.4	29.4	29.3	30.3	34.5	31.8	38.0	35.5	30.1	27.6	28.7	22.9	20.9	19.4	26.7	27.1
28	27.5	29.1	26.4	25.2	24.4	24.8	28.2	10.7	2.9	4.4	13.9	32.0	26.6	24.4	25.5	24.5	20.8	16.6	14.3	33.2	22.8	35.1	26.0	33.5
29	31.7	27.0	27.6	26.0	25.7	23.9	23.1	24.5	26.1	23.7	22.9	24.6	28.6	30.3	31.8	26.6	22.6	20.6	18.7	16.5	20.0	21.4	22.2	20.8
30	17.7	18.1	18.1	19.3	23.6	26.5	28.5	37.7	55.9	27.1	17.9	13.7	12.5	13.3	15.8	26.6	36.3	39.6	32.1	33.1	46.9	56.0	50.2	37.6
31	36.6	32.6	28.0	27.8	30.4	36.1	46.4	40.8	46.8	33.9	33.6	29.6	28.4	26.0	37.6	31.3	31.0	28.2	33.2	29.1	28.8	27.7	33.3	34.9

Monthly Exceedence Report

New Orleans - East Bank WWTP
June 2009

VEOLIA WATER

Date/Time	Description	Duration	Peek Value	Operator	Reason
06/05/2009 09:05:02	CO > 100 ppm	00:31:00	136.80	Jawanda Trimont	Adjusting Feed Rate
06/17/2009 09:58:06	CO > 100 ppm	00:13:00	105.20	Herbert Thomas	Maintenance Repair
06/28/2009 00:20:02	CO > 100 ppm	02:04:00	500.00	Joseph Edwards	Adjusting Air Flow
06/28/2009 08:53:02	CO > 100 ppm	00:54:00	124.40	Donald Trotter	Adjusting Feed Rate
06/28/2009 13:15:01	CO > 100 ppm	00:47:01	143.30	Donald Trotter	Maintenance Repair
06/29/2009 01:17:05	CO > 100 ppm	00:59:00	188.40	Billy Howard	FBI Offline
06/29/2009 07:17:03	CO > 100 ppm	01:19:00	332.50	Carl Kelly	Maintenance Repair

Monthly CO CEM Report

New Orleans - East Bank WWTP
Jun 01, 2009

VEOLIA WATER

Hourly CO Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
[illegible]	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.8	0.3	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	14.1	76.4	42.6	33.6	0.5	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.9	28.5	3.9	2.2	0.0	0.0	0.2	1.5	3.9	4.1	0.8	0.7	8.7	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	82.3	51.9	19.3	57.1	0.0	0.0	10.5	0.0	0.0	0.0	1.0	0.0	0.2	0.0	0.0
6	0.0	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.9	2.1	0.0	1.4	2.0	0.0	0.0	1.3	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.2	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.0	38.3	28.7	10.7	0.0	17.2	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	104.7	0.0	0.0	0.0	3.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	41.0	0.
18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.2	0.0	0.0
19	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.
[illegible]	0.0	0.0	0.0	0.0	0.0	0.0	0.0	41.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.
22	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.9	0.0	0.0	0.0	47.5	0.0	0.0	0.0	0.0	0.
23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	1.2	0.4	0.0	0.1	6.7	8.5	10.8	6.7	8.2	2.1	1.5	0.5	0.
24	2.9	0.4	0.1	0.4	0.0	0.7	0.0	0.0	0.0	1.6	0.0	0.0	0.0	0.0	0.0	0.1	0.0	2.0	0.0	0.2	0.2	4.0	0.2	0.
25	0.4	2.5	1.4	2.0	0.5	1.2	0.5	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.2	0.1	0.2	0.0	0.0	0.0	0.
26	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	1.0	0.3	0.0	0.
27	0.0	0.0	0.2	0.2	0.2	3.1	0.2	1.1	2.7	0.4	0.0	1.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.3	1.5	0.0	8.8	12.
28	30.1	406.5	291.9	11.2	3.2	0.7	0.0	3.0	13.9	117.4	27.5	32.8	0.0	42.6	97.2	77.2	1.7	0.3	0.1	25.0	33.1	39.1	15.5	11.
29	10.7	9.1	194.5	8.9	44.2	28.6	15.5	29.9	331.5	13.3	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.1	0.0	0.2	0.0	0.
30	0.0	0.0	0.0	6.0	10.2	10.5	46.5	1.5	1.6	0.5	0.6	1.7	2.7	0.2	0.8	1.5	1.1	0.4	0.7	0.0	9.9	12.1	39.1	0.

Monthly O2 CEM Report

New Orleans - East Bank WWTP
Jun 01, 2009

VEOLIA WATER

Hourly O2 Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	13.6	13.8	13.9	13.4	13.6	13.1	13.0	13.2	13.4	12.6	11.3	11.1	10.1	10.9	11.5	11.4	11.1	10.9	10.8	11.0	10.9	10.9	10.9	11.8
2	11.0	12.0	14.8	15.2	14.7	15.1	14.6	16.8	15.4	14.7	14.8	14.6	14.3	14.1	13.3	13.9	18.4	16.4	14.2	14.1	13.6	14.2	13.6	14.5
3	14.1	14.4	14.1	13.6	13.6	13.2	13.1	14.6	13.4	12.9	13.3	14.8	13.1	16.5	12.2	14.2	12.7	14.8	15.1	14.6	14.6	14.2	14.7	14.7
4	14.3	13.4	14.4	14.5	14.3	14.4	14.7	14.6	15.1	17.4	13.7	12.3	11.8	11.5	12.2	11.8	12.0	13.4	11.7	15.2	15.3	14.3	11.9	12.6
5	13.8	14.0	12.9	13.7	13.1	12.9	13.8	13.5	14.2	19.4	21.0	21.1	19.4	15.2	19.5	17.5	15.0	13.8	13.9	15.6	13.2	12.0	11.9	12.
6	12.2	12.3	12.6	12.6	12.2	12.9	13.7	13.4	12.9	12.6	12.7	12.7	12.0	11.1	13.6	13.1	12.8	12.8	13.1	13.7	12.6	12.3	13.4	13.5
7	13.4	13.3	13.1	12.6	12.9	12.3	12.1	11.5	11.4	14.0	13.8	14.0	13.8	14.4	14.2	14.2	14.3	14.2	14.2	14.5	14.2	14.0	13.9	14.6
8	13.9	14.2	14.0	14.0	14.5	14.2	13.8	13.0	13.4	16.9	16.7	16.5	16.3	16.3	16.2	16.9	16.8	14.7	14.2	13.5	13.5	14.4	14.8	14.3
9	14.5	14.2	14.4	14.6	14.4	13.3	13.2	13.1	13.1	11.4	12.6	12.9	12.9	12.8	12.9	13.0	13.1	13.3	13.6	14.1	13.9	13.9	14.0	14.
10	14.1	14.1	13.8	13.7	13.7	13.7	15.4	13.2	14.3	15.1	14.2	13.3	13.9	15.0	15.1	15.1	15.0	15.2	15.0	14.9	15.1	15.2	15.0	15.
11	14.9	14.8	15.2	15.3	15.4	15.3	15.4	15.0	15.2	15.2	15.1	15.3	15.4	15.4	15.3	15.2	15.2	15.2	15.0	15.1	15.2	15.4	15.2	15.
12	15.3	15.3	14.8	14.8	13.9	14.6	14.4	13.9	13.8	15.5	15.0	14.8	14.6	15.5	15.6	14.7	15.3	15.1	15.2	15.3	15.2	15.3	15.1	15.
13	15.2	14.9	14.2	14.9	14.5	14.2	14.1	13.7	14.2	15.2	15.0	15.0	15.3	15.2	15.0	15.0	15.1	15.4	15.4	15.3	15.2	15.3	15.2	15.
14	15.1	15.4	15.1	14.5	15.2	15.1	15.1	15.2	14.9	14.7	14.8	14.5	14.2	14.3	13.5	13.3	13.2	13.6	14.0	14.7	15.0	15.0	15.0	15.
15	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.
16	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	20.5	20.8	20.4	20.3	20.2	19.1	17.9	18.6	18.6	18.8	18.
17	19.0	18.9	19.1	19.0	18.7	18.4	18.4	18.3	18.4	18.3	15.4	12.5	13.1	12.8	12.4	11.8	12.6	13.7	13.0	12.6	12.8	13.6	15.1	14.
18	14.8	14.2	14.6	14.7	15.0	14.8	14.4	14.8	15.0	15.0	14.7	14.2	13.9	14.0	13.5	13.8	13.8	14.9	15.5	15.6	15.7	15.1	14.7	14.
[illegible]	13.6	13.2	13.6	13.4	12.7	14.6	16.0	13.7	13.5	14.5	16.3	14.5	13.2	12.7	13.5	13.4	13.0	12.8	12.3	12.4	12.7	12.9	13.2	15.
[illegible]	18.9	18.7	15.0	14.9	14.9	14.8	14.9	14.8	14.2	14.3	14.0	12.9	13.2	14.0	14.3	13.7	13.0	13.2	12.9	13.7	14.2	14.7	15.1	15.
21	15.4	15.5	15.3	15.1	15.3	15.2	15.4	16.1	15.2	15.0	15.3	14.5	15.4	14.8	15.3	14.8	14.6	14.4	13.8	13.3	13.9	14.1	14.1	14.
22	14.1	14.2	14.0	13.8	13.8	14.4	14.6	13.9	13.8	13.2	13.1	14.4	14.2	12.8	11.2	10.9	11.5	12.4	15.7	12.3	12.6	13.3	13.8	14.
23	13.8	14.0	14.0	13.8	13.4	13.4	13.0	13.1	12.2	12.1	12.5	12.3	12.8	12.4	13.6	13.1	12.7	12.4	11.9	11.7	12.2	12.6	13.2	13.
24	12.4	12.9	13.0	13.1	13.0	13.1	13.2	13.3	12.4	12.6	12.8	13.0	12.5	12.3	12.1	16.4	12.1	12.7	12.5	13.0	13.4	12.5	12.7	12.
25	13.4	12.6	12.5	11.7	11.4	11.0	10.7	11.2	12.3	12.1	14.5	13.7	13.3	13.0	12.7	14.0	12.5	12.2	11.6	12.3	11.9	11.7	11.7	11.
26	12.1	11.7	12.1	12.5	13.7	12.1	11.6	11.9	11.6	12.5	12.2	12.7	12.4	12.8	13.8	12.6	12.3	12.5	12.5	12.5	12.5	12.7	12.4	12.
27	11.8	12.1	12.5	11.7	12.0	11.5	11.2	11.0	11.4	12.0	12.5	12.6	11.8	11.6	12.7	12.9	12.7	16.8	15.7	13.8	13.9	15.5	12.1	12.
28	17.8	20.7	20.7	20.2	20.2	19.8	19.8	19.7	20.0	20.3	16.6	17.3	17.7	17.6	20.9	20.9	20.8	20.9	20.8	20.6	20.6	17.6	16.4	16.
29	16.8	18.9	20.6	19.5	19.6	19.8	19.7	19.0	19.3	16.5	17.8	15.2	14.2	13.6	14.3	13.1	13.8	13.5	14.6	13.7	12.8	12.4	14.8	15
30	13.6	13.4	13.4	12.3	13.8	16.8	13.0	12.9	12.8	13.0	13.1	13.1	12.5	11.9	11.1	11.7	12.2	12.2	12.8	14.0	11.7	11.4	10.4	12

Monthly O2 Analyzer Report

New Orleans - East Bank WWTP
Jun 01, 2009

VEOLIA WATER

Hourly O2 Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	9.2	9.2	9.3	9.4	9.4	9.4	8.7	9.5	9.5	9.4	9.6	9.4	8.6	9.2	9.7	9.6	9.4	9.2	9.1	9.3	9.2	9.2	9.2	10.
2	9.3	9.4	9.4	9.4	9.3	9.3	8.7	11.1	10.0	8.9	9.0	9.0	9.2	8.8	7.8	7.8	12.9	11.2	7.5	8.3	8.6	9.1	8.9	9.
3	8.7	8.8	8.8	8.7	8.8	8.7	8.4	8.6	8.7	8.5	8.9	10.9	8.8	10.8	7.7	9.7	7.8	9.4	10.1	10.2	10.3	10.3	11.2	10.
4	10.5	9.6	10.0	10.1	10.0	10.2	9.9	10.6	11.0	14.0	8.1	7.4	7.3	6.8	7.7	7.1	7.2	8.8	6.7	10.6	10.0	10.0	6.1	7.
5	8.3	8.3	7.6	8.0	8.1	8.1	8.0	8.6	8.9	14.4	16.5	16.0	15.0	10.7	15.3	12.4	8.7	8.8	8.5	10.5	7.9	7.4	7.4	7.
6	7.8	7.5	7.4	7.4	7.4	7.4	7.3	7.5	7.5	8.1	7.8	8.0	7.6	6.8	8.1	8.3	8.0	7.8	8.1	9.2	8.4	7.8	8.6	8.
7	8.2	7.8	7.5	7.5	7.6	7.7	7.7	7.6	7.3	9.0	8.4	8.2	8.3	9.2	8.7	8.7	8.6	8.5	8.5	8.5	9.0	8.5	8.5	8.
8	8.6	8.8	8.9	8.9	9.1	9.1	8.0	8.4	8.6	12.1	11.8	11.5	11.4	11.4	11.4	12.3	12.6	9.3	9.1	8.7	9.5	9.8	9.8	9.
9	9.5	9.5	9.6	9.7	9.8	9.6	9.4	9.4	9.4	8.0	8.8	8.8	8.4	8.5	8.4	8.3	8.6	8.5	8.3	8.5	8.3	8.5	8.4	8.
10	8.2	8.3	8.4	8.2	8.7	9.5	11.1	8.7	9.2	9.7	9.7	9.2	9.5	9.8	10.0	9.9	9.8	9.9	9.8	9.8	9.6	10.0	9.5	9.
11	9.3	9.3	9.4	9.5	9.6	9.6	9.5	9.6	9.8	9.4	9.6	9.8	9.8	10.1	10.0	10.0	10.0	10.0	10.1	9.9	10.0	10.2	9.7	9.
12	9.6	9.5	9.6	9.6	9.6	10.5	9.7	9.7	9.7	10.2	9.7	9.6	9.2	10.3	10.6	9.6	10.0	10.1	10.2	10.1	10.1	10.0	10.1	10.
13	10.2	9.9	9.2	9.9	9.7	9.6	9.6	9.8	10.0	9.6	9.4	9.7	10.0	10.0	10.1	10.0	10.0	10.0	10.0	10.0	10.0	10.0	9.8	9.
14	9.5	9.8	9.4	9.0	9.3	9.5	8.9	9.4	9.4	9.4	9.3	9.3	9.4	9.7	9.3	9.3	9.3	9.3	9.4	9.6	10.3	10.3	10.3	10.
15	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.
16	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	16.3	17.2	17.0	17.0	17.0	15.7	14.4	14.9	14.7	14.6	14.
17	14.6	14.6	14.7	14.7	14.6	14.6	14.7	14.8	14.7	14.7	10.0	8.3	8.7	8.5	8.1	7.6	8.3	9.2	8.8	8.8	8.4	8.8	10.7	9.
18	10.2	9.6	10.1	10.3	10.7	10.8	10.3	10.6	10.5	10.4	10.3	10.1	9.4	9.3	9.5	10.0	9.8	11.0	11.0	11.3	11.3	10.6	10.3	9.
19	9.0	8.4	8.9	8.9	8.5	10.7	10.0	8.9	8.9	9.0	11.8	9.7	8.4	8.2	8.4	8.5	8.5	8.4	8.3	8.4	8.2	8.3	8.3	10.
20	15.1	14.6	9.3	9.0	9.4	9.0	9.3	9.2	8.6	8.7	9.0	8.7	8.8	9.2	10.0	9.1	8.6	8.7	8.6	8.6	8.8	9.6	10.2	10.
21	10.2	10.1	10.0	9.8	10.2	10.1	9.9	11.5	10.4	10.0	10.4	9.8	10.7	10.0	10.6	9.8	9.8	9.8	9.5	8.7	8.7	8.8	8.8	8.
22	8.4	8.6	8.4	8.2	8.2	8.9	9.2	8.4	9.2	8.6	8.0	9.6	8.3	7.9	6.8	6.7	7.4	7.9	11.6	7.5	7.5	8.2	8.4	8.
23	8.6	8.5	8.5	8.3	7.7	7.6	7.2	7.5	7.5	7.8	8.2	7.6	7.5	7.6	8.8	7.1	6.3	6.1	6.3	6.2	6.5	7.2	7.8	7.
24	7.0	7.4	7.3	7.4	7.4	7.3	8.0	7.9	7.7	7.4	7.7	7.9	7.9	7.5	7.4	13.0	8.3	8.3	7.9	8.1	8.4	7.9	7.7	7.
25	8.3	8.2	8.2	7.1	7.3	7.3	7.2	7.5	8.5	8.0	10.0	8.7	8.0	7.9	7.6	9.5	7.8	7.4	7.3	7.3	7.5	7.9	8.0	7.
26	7.9	8.0	8.0	8.0	9.4	8.2	7.6	7.9	7.5	8.0	7.6	7.9	7.9	8.2	9.3	8.0	7.7	7.7	7.5	7.4	7.2	7.9	7.6	7.
27	7.6	7.5	7.5	7.5	7.6	7.0	7.1	7.1	7.1	7.4	7.9	7.4	7.4	7.3	7.4	7.4	7.6	12.5	11.6	9.0	8.8	11.2	7.4	6.
28	13.9	17.2	16.7	16.6	16.7	16.8	16.9	16.5	16.1	16.2	12.5	12.6	13.7	12.6	17.6	17.9	18.3	17.7	16.2	10.9	9.9	9.1	9.4	10.
29	11.1	12.3	13.2	13.8	14.1	14.2	14.5	14.8	14.8	12.6	14.3	10.7	9.2	8.6	9.9	8.3	9.0	9.0	10.0	8.5	8.0	7.8	10.5	10.
30	8.3	9.3	9.1	7.1	8.3	12.9	6.1	7.6	7.2	7.4	7.7	7.8	7.7	8.2	7.0	6.8	7.0	7.3	8.3	10.0	6.9	6.9	5.8	7.

Monthly Moisture CEM Report

New Orleans - East Bank WWTP
Jun 01, 2009

VEOLIA WATER

Hourly Moisture Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	32.3	32.9	33.1	30.1	30.7	27.9	31.9	27.9	28.8	24.8	15.6	15.7	15.7	15.5	15.4	15.4	15.3	15.3	15.2	15.5	15.7	16.1	15.8	15.1
2	15.6	21.1	36.0	37.8	36.9	38.0	38.8	34.5	35.6	39.2	38.7	37.9	35.8	36.9	41.2	43.9	29.8	33.3	46.7	40.8	36.5	35.8	34.2	37.6
3	37.9	38.7	37.2	35.4	35.0	33.6	35.4	40.9	35.1	33.6	33.1	27.4	35.8	37.7	38.4	32.2	38.0	36.0	33.3	30.3	29.5	26.9	24.0	23.1
4	26.2	28.6	30.3	29.9	29.6	29.1	31.4	27.2	27.1	19.8	42.0	39.0	37.8	40.5	36.5	39.6	39.6	35.0	42.6	31.3	34.9	30.6	46.5	40.2
5	39.2	40.7	40.7	41.3	38.3	37.0	42.0	36.2	36.8	26.7	21.9	23.8	22.9	29.1	21.3	30.0	41.7	35.5	38.8	33.5	40.2	38.0	37.5	36.5
6	36.2	38.8	41.1	41.5	39.4	42.4	46.5	43.7	41.8	35.7	38.6	36.7	36.1	38.1	40.6	36.2	37.1	39.1	38.1	33.3	33.3	36.1	35.8	35.8
7	38.7	41.4	42.6	40.0	40.9	37.7	36.0	33.6	35.9	35.7	39.3	41.4	40.1	36.3	38.6	38.6	39.5	40.0	39.8	40.7	37.0	38.8	38.9	38.5
8	38.4	38.0	36.2	36.5	37.0	35.7	39.0	34.9	35.9	28.6	29.5	30.5	29.7	30.0	29.4	27.3	26.4	36.4	36.0	35.5	29.2	32.1	33.8	33.7
9	34.5	33.1	33.4	33.3	31.9	27.8	28.5	27.9	27.5	1.$	30.2	31.5	34.7	33.9	34.9	36.5	33.7	36.1	38.8	39.5	39.7	38.7	39.9	40.2
10	41.7	41.5	39.1	40.2	36.4	31.2	27.0	34.3	35.1	35.6	31.8	30.5	31.5	35.0	33.6	34.5	34.8	34.4	34.5	33.9	36.4	34.0	36.6	36.9
11	37.8	36.8	38.2	37.8	37.1	37.1	36.0	36.0	35.5	37.8	36.5	35.6	36.3	34.4	34.5	34.2	33.8	34.2	32.5	34.7	34.6	34.1	36.0	37.2
12	37.0	38.1	35.1	35.1	30.7	28.2	32.7	30.0	29.5	34.0	35.3	34.7	36.7	33.6	31.6	34.5	34.2	33.5	32.5	33.5	33.8	34.5	33.5	34.2
13	33.2	33.1	34.9	33.5	33.2	32.5	32.1	28.2	29.7	37.0	37.4	35.0	34.4	34.3	32.5	32.8	33.6	34.7	35.1	34.7	34.3	34.5	35.3	36.7
14	37.4	36.2	38.1	37.9	39.0	36.8	40.4	37.8	37.0	35.9	37.0	35.9	33.8	32.2	30.6	29.6	29.7	31.6	32.3	34.2	31.7	31.3	31.3	31.[illegible]
15	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.[illegible]
16	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	20.4	17.2	16.8	16.3	15.9	18.2	19.8	20.3	20.8	22.2	22.[illegible]
17	23.0	22.6	23.0	22.9	21.7	20.2	20.3	19.6	19.8	19.5	36.7	33.8	33.5	33.7	34.4	35.3	33.8	32.7	32.2	29.7	34.5	35.7	30.6	34.[illegible]
18	31.2	32.3	30.8	30.0	29.0	27.1	28.4	28.2	29.5	30.6	30.0	29.2	32.3	33.0	29.8	27.5	29.0	26.3	28.9	27.9	27.7	29.5	30.0	33.[illegible]
19	33.5	36.1	34.7	33.8	32.7	27.5	26.1	35.2	34.2	38.0	27.7	33.4	36.3	35.2	37.8	36.8	34.6	34.4	32.4	32.1	35.2	35.7	37.0	32.[illegible]
[illegible]	20.2	21.9	37.9	39.4	36.9	39.0	37.6	38.0	39.4	39.1	35.8	32.5	33.3	34.4	30.2	33.5	33.7	33.5	32.7	37.1	38.0	35.2	32.4	33.[illegible]
21	33.8	34.4	34.7	34.8	33.3	33.2	34.5	28.8	31.2	33.6	31.8	32.3	30.3	32.4	30.7	33.2	32.5	31.9	31.0	34.4	37.0	37.3	37.5	39.[illegible]
22	40.2	39.3	40.0	40.9	41.0	38.4	38.4	39.5	33.3	34.4	38.6	33.7	41.3	37.8	39.3	38.9	35.2	36.5	26.7	38.9	40.1	38.2	39.1	38.[illegible]
23	37.3	38.8	39.5	40.0	42.6	43.0	42.8	42.7	38.8	35.6	34.5	38.5	41.2	38.4	35.4	45.6	50.4	50.3	46.5	46.4	46.6	43.1	40.7	40.[illegible]
24	43.6	42.1	43.5	43.4	42.5	44.2	41.0	40.0	38.0	40.5	39.3	39.1	36.6	38.7	38.8	22.3	31.6	34.4	36.1	37.9	37.6	36.9	39.0	39.[illegible]
25	38.7	35.3	34.5	39.2	35.4	33.5	34.4	33.1	31.5	33.4	31.9	36.6	39.7	39.3	39.8	32.5	37.2	38.4	36.9	40.2	36.7	32.5	31.3	31.[illegible]
26	34.3	31.8	33.6	35.5	32.0	32.6	32.5	33.3	35.3	36.0	37.9	37.5	36.5	35.9	33.1	36.3	37.0	38.4	40.1	40.9	42.5	37.3	38.3	37.[illegible]
27	35.5	37.8	39.7	35.3	36.6	38.6	37.2	35.6	37.8	37.8	37.0	41.2	37.7	36.5	41.3	42.1	39.9	25.7	26.3	34.8	36.5	27.7	39.2	45.[illegible]
28	22.9	17.2	19.4	17.6	16.9	15.0	14.7	16.4	19.0	20.3	24.6	27.5	22.8	1.$	15.7	14.5	11.9	15.2	22.1	46.9	52.0	47.6	41.9	39.[illegible]
29	33.2	34.6	35.3	28.6	27.5	28.2	26.6	21.9	23.2	23.1	20.0	30.3	35.2	36.4	30.7	36.7	34.9	32.8	32.0	37.9	37.4	36.9	29.8	28.[illegible]
30	38.3	30.4	31.7	42.2	40.9	25.4	53.3	40.7	43.3	43.3	41.2	40.4	38.6	31.7	36.6	41.6	42.9	39.9	34.9	28.2	40.8	38.9	44.4	38.[illegible]

Monthly NOX CEM Report

New Orleans - East Bank WWTP
Jun 01, 2009

VEOLIA WATER

Hourly NOX Averages

D	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	32.7	30.1	28.8	31.5	30.7	30.6	31.7	29.1	31.9	38.6	45.9	57.3	46.9	33.4	43.5	49.8	46.1	41.6	31.8	26.6	33.3	33.1	31.8	43.4
2	27.1	24.0	16.3	13.6	13.8	12.2	17.8	23.8	27.9	23.2	21.6	23.9	25.9	25.6	28.2	26.9	22.9	19.3	27.3	26.5	24.7	26.2	24.1	22.6
3	24.1	21.3	24.0	24.6	26.1	25.3	25.5	21.1	25.4	25.6	21.5	38.3	35.2	23.7	35.8	41.4	38.7	41.0	35.1	33.8	29.5	27.3	33.8	19.9
4	13.4	26.2	27.0	20.6	23.2	22.8	21.6	15.1	16.8	26.9	43.7	51.0	54.1	63.8	41.7	49.8	45.6	31.2	18.0	30.7	24.0	31.2	31.6	36.6
5	23.8	18.8	30.2	25.2	27.4	35.7	37.7	30.7	31.3	11.0	1.1	1.0	2.9	45.9	18.9	31.1	41.8	31.3	23.7	38.5	34.9	34.8	46.7	50.6
6	42.7	36.7	41.4	43.7	46.5	40.2	32.6	32.2	36.4	29.4	26.0	21.3	23.6	38.8	38.0	30.6	25.1	26.0	43.0	38.6	28.4	51.5	46.1	29.5
7	39.9	43.4	36.7	37.2	38.2	42.1	39.8	45.4	52.0	28.6	26.4	33.7	40.1	41.8	31.8	27.0	35.2	40.3	40.0	42.0	29.0	28.4	31.3	34.7
8	35.3	36.4	45.5	46.4	31.7	24.5	32.5	44.2	38.3	40.8	30.7	33.2	37.7	37.9	36.8	36.5	28.3	30.3	20.1	21.0	29.6	26.6	22.7	20.3
9	22.2	29.4	26.6	20.9	21.0	21.8	29.1	32.2	35.5	34.5	21.3	25.4	20.2	23.8	23.3	28.5	35.1	32.1	31.7	28.7	33.9	34.2	39.1	30.6
10	34.0	33.6	32.1	34.5	37.1	37.7	51.1	32.9	32.5	28.0	33.8	37.4	36.3	31.9	27.8	29.2	29.5	25.8	26.3	26.5	23.4	26.0	22.3	21.9
11	22.9	24.0	22.8	21.8	21.5	22.4	20.0	22.9	22.1	22.2	27.6	26.9	28.7	26.4	27.1	30.8	29.7	28.2	28.5	27.0	24.8	25.0	23.2	22.4
12	23.1	22.6	23.7	24.9	27.9	32.4	27.8	28.7	32.2	17.3	19.6	27.6	44.5	29.0	12.8	31.9	31.9	35.0	33.5	25.4	27.1	25.2	23.8	18.4
13	17.2	17.2	32.7	21.4	20.6	26.0	30.3	27.1	17.6	19.1	28.6	32.1	22.7	23.5	24.3	25.2	25.9	24.6	25.0	23.4	22.2	19.4	15.9	23.4
14	23.4	14.3	16.5	25.5	25.6	19.4	27.8	23.8	24.1	26.7	24.8	26.6	25.8	15.6	18.3	24.6	30.6	31.6	31.8	27.9	18.6	18.8	18.8	18.4
15	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8
16	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	2.1	1.3	2.7	3.1	2.6	3.8	3.7	2.9	3.0	2.8	2.4
17	2.6	2.7	2.5	2.5	2.9	3.4	3.5	3.6	3.7	3.7	38.0	56.5	30.0	31.6	34.8	42.7	38.2	29.9	26.6	22.7	27.0	37.3	41.8	38.4
18	36.2	28.1	30.2	31.7	32.9	33.0	34.4	32.1	29.2	36.4	43.2	27.8	37.9	47.0	49.2	46.5	45.6	57.1	42.3	32.0	29.2	42.1	33.8	40.4
19	43.7	44.3	43.7	44.7	46.6	44.0	46.4	40.0	38.0	36.6	31.8	39.7	34.4	28.3	26.4	31.4	32.2	31.5	30.2	28.6	28.1	25.3	22.9	35.4
20	30.1	25.3	29.0	24.1	20.7	21.8	18.8	20.3	22.2	22.8	31.9	30.3	29.1	30.2	41.5	27.6	28.7	30.5	28.0	25.0	25.3	24.0	21.2	21.4
21	19.6	19.8	19.8	24.7	23.0	21.4	16.5	40.6	27.1	27.9	15.3	21.6	31.6	28.7	15.7	27.4	40.6	29.6	23.4	23.8	20.0	17.8	17.7	16.4
22	21.4	23.2	20.0	25.7	27.9	32.1	20.4	21.8	34.3	16.9	20.9	36.4	19.0	18.9	21.8	39.4	30.8	31.1	42.1	24.0	35.1	27.1	22.0	20.4
23	20.9	19.5	17.2	23.2	29.8	23.4	21.4	23.5	26.2	29.0	21.1	20.2	21.5	20.3	24.1	22.5	22.6	22.2	23.3	25.6	22.0	20.0	20.8	18.4
24	20.9	20.2	19.4	18.4	19.9	19.8	18.3	18.7	20.8	19.5	25.5	23.8	18.6	18.3	25.7	32.3	26.7	30.2	21.8	30.6	24.0	25.3	19.9	20.4
25	26.2	22.4	26.2	25.9	25.8	25.2	28.6	24.9	27.4	19.9	25.9	17.3	20.2	20.2	21.8	36.5	29.1	29.1	31.8	27.4	27.8	29.7	33.1	31.4
26	26.5	24.3	20.4	18.1	25.9	23.5	26.0	23.1	27.7	22.4	26.4	25.7	26.6	23.3	22.1	20.0	22.7	23.9	22.0	19.8	20.7	21.3	21.1	21.4
27	24.3	22.2	19.6	19.4	17.1	24.7	25.8	27.7	28.1	25.9	20.3	22.9	24.1	25.6	21.9	23.5	21.8	27.2	23.1	20.6	24.3	23.9	19.9	26.4
28	28.8	18.2	6.1	4.6	4.9	7.0	5.3	11.4	11.4	2.9	5.6	17.4	35.6	33.0	1.2	0.4	1.2	0.3	0.5	1.2	1.4	13.7	14.5	13.4
29	17.6	13.3	3.5	13.5	12.4	9.8	10.7	20.1	12.3	5.6	6.9	30.4	23.9	24.6	21.7	23.6	28.7	21.3	22.7	17.1	18.4	23.1	21.3	24.4
30	15.6	14.5	26.1	26.9	29.0	22.3	28.9	23.8	21.0	20.0	22.7	19.9	29.6	21.1	21.8	22.2	20.1	19.1	20.6	17.5	24.7	25.1	33.2	20.0

Section Three

Quarterly National Emissions Standards for Hazardous Air Pollutants (NESHAP) Report
Mercury and Beryllium
April 1, 2009 to June 30, 2009
40 CFR Part 61, Subpart C & E

Data Submitted:

- ***NESHAP's analytical results for Mercury and Beryllium.***

CHEMTEX
Environmental & Industrial Hygiene Services

3082 25th Street, Port Arthur, Texas 77642 • (409) 983-4575 FAX (409) 982-1522
5544 Leopard Street, Corpus Christi, Texas 78408 • (361) 299-9900 FAX (361) 299-1155
138 S. Cities Service Hwy., Sulphur, Louisiana 70663 • (337) 626-2121 FAX (337) 626-2126

Client: ***Veolia Water North America***
6501 Florida Ave.
New Orleans, LA 70117

RECEIVED 6/30/09

Report Date: 06/24/09
Sample Matrix: Sludge
Date Collected: 06/09-10/09
Time Collected: 07:00-07:00
Collected By: Client
Date Received: 06/10/09
Time Received: 12:30pm
CHEMTEX FILE #: P9060254

Attn: ***Mr. Kevin Servat*** Kevin.servat@veoliawaterna.com
Phone: 1-504-277-5400; Fax: 1-504-277-5454

RESULTS OF ANALYSIS

CHEMTEX #	Sample Identification	Parameter	Units	Results	MDL
P9060254	New Orleans East Bank WWTP	Total Beryllium	mg/kg or ppm	0.370	2.5
		Beryllium Emmissoin Rate	grams/day	8.05	--
		Total Mercury	mg/kg or ppm	0.463	0.20
		Mercury Emmissoin Rate	grams/day	10.07	--
Method Blank	Ottawa Sand	Total Beryllium	mg/kg or ppm	< 2.5	2.5
		Total Mercury	mg/kg or ppm	< 0.20	0.20

MDL: Method Detection Limit

Analysis performed at CHEMTEX, Sulphur, LA 70663.

LABORATORY QUALITY ASSURANCE/QUALITY CONTROL DATA

LABORATORY CONTROL SAMPLES (LCS) RECOVERY

Parameter	Units	True Value	Obtained Value	Recovery (%)	Limits (%)
Total Beryllium	mg/kg	25.00	25.49	102	80-120
Total Mercury	mg/kg	0.5	0.5	100	80-120

METHOD REFERENCES/ANALYSIS DATES & ANALYSTS

Parameter	Method Reference	Date Analyzed/Analyst
Total Beryllium	EPA Method 6010B	06/12/09 KS/SS
Total Mercury	EPA Method 7471A	06/11/09 KS/SS

CNReddy

Dr. C. N. Reddy, Ph.D., CIH/ASP
Director

kml*/CNR

NOTICE/DISCLAIMER: The analytical results, opinions or interpretations contained in this report are based upon information and material supplied by the client for whose exclusive and confidential use this report has been made. No person or entity other than the client may rely on this report. Any such reliance will be unjustified. Any person, other than the client, that reads this report does so at his or her own risk. The analytical results, opinions and/or interpretations expressed herein represent the best judgment of Chemtex, based on the information and instructions received from the client. Chemtex makes no warranty or representation, express or implied, of any type, and expressly disclaims same. This report shall not be reproduced, in whole or in part, without the written approval of Chemtex. In no event shall Chemtex be responsible for any damage greater than the amount that it received for the analysis performed.

NESHAP Mercury & Beryllium Testing 2009

Sewerage and Water Board of New Orleans
East Bank WWTP (NPDES Permit LA0038091)

		Time			Charging Rates			
	Date	Begin	End		Initial	Final	Gallons	GPM
Shift #1	6/9/2009	0700	1900		3321452	3334056	12,604	18
Shift #2	6/9-10/2009	1900	0700		3334056	3345996	11,940	17
					Total		24,544	18
					Average		12,272	

K. Servat
Kevin Servat
Project Manager

6/10/2009
Date

VEOLIA WATER

FIELD CHAIN OF CUSTODY RECORD

FIELD MONITORING PROGRAM

SAMPLERS (SIGNATURES): Marvin Perry

Veolia Operations

FACILITY	SAMPLE SOURCE	COMPOSITING PERIOD: SAMPLING BEGINS DATE	SAMPLING BEGINS TIME	SAMPLING ENDS DATE	SAMPLING ENDS TIME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	G/C	FLOW MGD	CONTAINER VOLUME	G/P	Volatile Organics	Pesticides/PCB's	Trace Metals	Cyanide	Phenols	Oil and Grease	Solids	BOD	Ammonia Nitrogen	Phosphorous	Coliform	pH	Hg + Be NESHPs	Preservation	COMMENTS LAB ID
New Orleans East Bank WWTP	Sludge Cake	6-9-09	0700	6-10-09	0700	6-10-09	0730	C	-	5-gal	P													X		P906025

RELINQUISHED BY	DATE	TIME	RECEIVED BY	RELINQUISHED BY	DATE	TIME	RECEIVED BY
Marvin Perry	6-10-09	0810	K. Servat	K. Servat	6/10/09	12:30	FEDEX
RELINQUISHED BY	DATE	TIME	RECEIVED BY	RELINQUISHED BY	DATE	TIME	RECEIVED BY
RELINQUISHED BY	DATE	TIME	RECEIVED BY	RELINQUISHED BY	DATE	TIME	RECEIVED BY

REMARKS: Veolia Water Care of Kevin Servat 504-277-5400 ; Fax # 504-277-5454

VWNA 3013 (5/04)

Section Four

Quarterly Fluid Bed Incinerator
Sulfur Report
April 1, 2009 to June 30, 2009
40 CFR Part 61, Subpart C & E

Data Submitted:

- ***Second Quarter analytical results***
- ***Second Quarter sludge charging rates***

Sulfur Emmisions Report
East Bank
4/1/2009 TO 6/30/2009

Date	Sludge Inc Tons	Inc. hrs. hrs	T. Sulfur mg/kg	SOx lb/hr
4/1/2009	28.9	24.0	310.0	2.84
4/2/2009	29.9	22.7		
4/3/2009	25.9	21.7		
4/4/2009	0.6	1.6		
4/5/2009	0.0	0.0		
4/6/2009	0.6	0.3		
4/7/2009	0.5	0.3		
4/8/2009	1.8	2.9		
4/9/2009	24.1	20.4	6,600.0	50.29
4/10/2009	22.4	24.0		
4/11/2009	24.9	24.0		
4/12/2009	29.1	23.6		
4/13/2009	23.2	21.2	140.0	1.03
4/14/2009	0.5	1.0		
4/15/2009	33.1	22.6		
4/16/2009	14.0	5.0		
4/17/2009	15.1	23.4		
4/18/2009	13.7	24.0		
4/19/2009	15.0	24.0		
4/20/2009	12.3	14.1		
4/21/2009	31.2	23.5	1,000.0	9.88
4/22/2009	33.4	24.0		
4/23/2009	30.8	24.0		
4/24/2009	36.6	23.2		
4/25/2009	34.4	24.0		
4/26/2009	21.7	24.0		
4/27/2009	30.5	22.3		
4/28/2009	25.8	24.0	730.0	5.97
4/29/2009	26.3	23.7		
4/30/2009	31.7	24.0		
5/1/2009	16.1	24.0		
5/2/2009	21.5	23.6		
5/3/2009	24.2	24.0		
5/4/2009	17.1	23.8		
5/5/2009	15.4	24.0		
5/6/2009	21.3	24.0		
5/7/2009	3.6	3.5	810.0	0.91
5/8/2009	30.3	15.5		
5/9/2009	24.0	24.0		
5/10/2009	22.6	24.0		
5/11/2009	24.7	23.5		
5/12/2009	24.8	22.8	1,200.0	9.41
5/13/2009	14.0	17.9		
5/14/2009	19.7	23.3		
5/15/2009	23.7	24.0		
5/16/2009	31.0	23.6		
5/17/2009	18.9	23.3		
5/18/2009	19.8	20.8		
5/19/2009	20.7	23.6	1,100.0	7.21
5/20/2009		0.9		
5/21/2009		0.0		
5/22/2009	13.2	14.0		
5/23/2009	18.4	24.0		
5/24/2009	2.8	6.2		
5/25/2009	14.7	18.6		
5/26/2009	19.3	24.0		
5/27/2009	18.0	22.0		

Sulfur Emmisions Report
East Bank
4/1/2009 TO 6/30/2009

Date	Sludge Inc Tons	Inc. hrs. hrs	T. Sulfur mg/kg	SOx lb/hr
5/28/2009	37.4	20.3		
5/29/2009	21.5	24.0	920.0	6.26
5/30/2009	22.2	24.0		
5/31/2009	24.5	24.0		
6/1/2009	19.8	24.0		
6/2/2009	30.7	23.5	920.0	8.94
6/3/2009	9.1	22.4		
6/4/2009	37.5	21.9		
6/5/2009	20.3	18.0		
6/6/2009	25.5	24.0		
6/7/2009	29.1	24.0		
6/8/2009	20.9	23.2		
6/9/2009	23.5	24.0	530.0	3.95
6/10/2009	17.5	24.0		
6/11/2009	20.8	24.0		
6/12/2009	20.7	24.0		
6/13/2009	21.2	24.0		
6/14/2009	18.7	24.0		
6/15/2009	3.3	2.9		
6/16/2009	13.3	7.7		
6/17/2009	20.5	21.8	720.0	4.67
6/18/2009	23.4	24.0		
6/19/2009	19.6	24.0		
6/20/2009	37.0	23.9		
6/21/2009	22.3	24.0		
6/22/2009	24.0	24.0		
6/23/2009	25.9	24.0		
6/24/2009	20.0	23.6	480.0	3.04
6/25/2009	24.6	23.8		
6/26/2009	31.7	24.0		
6/27/2009	16.5	24.0		
6/28/2009	0.6	4.6		
6/29/2009	20.2	20.4		
6/30/2009	35.9	24.0		
Average	20.9	19.8	1,189.2	8.80
Total	1,857.5	1,798.4	15,460.0	114.41
Minimum	0.0	0.0	140.0	0.91
Maximum	37.5	24.0	6,600.0	50.29

Section Five

Quarterly Fluid Bed Incinerator Preventive Maintenance Records April 1, 2009 to June 30, 2009 40 CFR Part 60, Subpart A & O and 40 CFR Part 503

Data Submitted:

- ***FBI-CEM operation records***
- ***Preventive maintenance records***
- ***FBI-Daily equipment inspection log***
- ***FBI-Oxygen analyzer daily calibration records***
- ***FBI-Plume observation log***

Note:

The Fluid Bed Incinerator operates under the 40 CFR Part 69, Subparts A & O and 40 CFR Part 503 regulations. This report satisfies paragraph 61, c of the consent decree. Verifying operation and maintenance of the FBI is in accord with the Fluid Bed Incineration Operation & Maintenance Plan previously submitted. Section 5 also satisfies Section 8 (Preventive Maintenance) of the FBI Operation & Maintenance plan that is different from the Sewerage & Water Board Preventive Maintenance Program.

Hours

Runtime:	705:29:00	97.98%
Downtime:	14:31:00	2.02%
Total:	720:00:00	100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

April 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
04/01/2009 00:00:00	04/01/2009 10:22:00	Incinerator Online	10:22:00		Billy Howard
04/01/2009 10:22:00	04/01/2009 10:26:00	Calibration Gas Valve Open		00:04:00	Jawanda Trimont
04/01/2009 10:26:00	04/16/2009 15:03:00	Incinerator Online	364:37:00		Jawanda Trimont
04/16/2009 15:03:00	04/17/2009 05:30:00	Incinerator Offline		14:27:00	Herbert Thomas
04/17/2009 05:30:00	05/01/2009 00:00:00	Incinerator Online	330:30:00		Billy Howard

Hours

Runtime:	693:27:00	93.21%
Downtime:	50:33:00	6.79%
Total:	744:00:00	100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

May 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
05/01/2009 00:00:00	05/07/2009 11:10:00	Incinerator Online	155:10:00		Jawanda Trimont
05/07/2009 11:10:00	05/08/2009 13:59:01	Incinerator Offline		26:49:01	Jawanda Trimont
05/08/2009 13:59:01	05/13/2009 11:50:00	Incinerator Online	117:50:59		Steve Shulin
05/13/2009 11:50:00	05/13/2009 15:27:00	Incinerator Offline		03:37:00	Jawanda Trimont
05/13/2009 15:27:00	05/13/2009 15:45:01	Incinerator Online	00:18:01		Jawanda Trimont
05/13/2009 15:45:01	05/13/2009 16:26:00	Incinerator Offline		00:40:59	Jawanda Trimont
05/13/2009 16:26:00	05/24/2009 16:09:01	Incinerator Online	263:43:01		Jawanda Trimont
05/24/2009 16:09:01	05/25/2009 11:35:01	Incinerator Offline		19:26:00	Herbert Thomas
05/25/2009 11:35:01	06/01/2009 00:00:00	Incinerator Online	156:24:59		Herbert Thomas

Hours

Runtime: 686:39:59 95.37%

Downtime: 33:20:01 4.63%

Total: 720:00:00 100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

June 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
06/01/2009 00:00:00	06/05/2009 08:35:00	Incinerator Online	104:35:00		Theodore Stewart
06/05/2009 08:35:00	06/05/2009 11:14:00	Incinerator Offline		02:39:00	Jawanda Trimont
06/05/2009 11:14:00	06/15/2009 10:15:01	Incinerator Online	239:01:01		Jawanda Trimont
06/15/2009 10:15:01	06/15/2009 10:15:01	System Reset		00:00:00	********
06/15/2009 10:15:01	06/15/2009 10:16:01	Incinerator Online	00:01:00		********
06/15/2009 10:16:01	06/15/2009 10:16:01	System Reset		00:00:00	********
06/15/2009 10:16:01	06/16/2009 11:19:00	Incinerator Online	25:02:59		********
06/16/2009 11:19:00	06/16/2009 11:29:00	No CEMS data - Driver Down		00:10:00	Jawanda Trimont
06/16/2009 11:29:00	06/16/2009 12:04:00	Incinerator Online	00:35:00		Jawanda Trimont
06/16/2009 12:04:00	06/16/2009 17:33:01	Incinerator Offline		05:29:01	Jawanda Trimont
06/16/2009 17:33:01	06/28/2009 01:19:00	Incinerator Online	271:45:59		Jawanda Trimont
06/28/2009 01:19:00	06/28/2009 08:44:00	Incinerator Offline		07:25:00	Joseph Edwards
06/28/2009 08:44:00	06/28/2009 13:22:00	Incinerator Online	04:38:00		Donald Trotter
06/28/2009 13:22:00	06/28/2009 13:27:01	Incinerator Offline		00:05:01	Donald Trotter
06/28/2009 13:27:01	06/28/2009 13:35:01	Incinerator Online	00:08:00		Donald Trotter
06/28/2009 13:35:01	06/28/2009 14:54:00	Incinerator Offline		01:18:59	Donald Trotter
06/28/2009 14:54:00	06/28/2009 14:59:00	Incinerator Online	00:05:00		Donald Trotter
06/28/2009 14:59:00	06/29/2009 07:12:00	Incinerator Offline		16:13:00	Donald Trotter
06/29/2009 07:12:00	07/01/2009 00:00:00	Incinerator Online	40:48:00		Carl Kelly

VEOLIA WATER

FLUID BED INCINERATOR PM REPORT

APRIL 1, – JUNE 30, 2009

DESCRIPTION	NO.of PM COMPLETED
Total Monthly Preventive Maintenance (PM)	70
Total Quarterly Preventive Maintenance (PM)	3
Total Semi-Annual Preventive Maintenance (PM)	3
Total Annual Preventive Maintenance (PM)	2
Total Preventive Maintenance Submitted	**78**

WO No. 07-2232

FBI DUCT DAMPERS - Q - O

Task No. FBIDUCT-Q

Assigned By KELLY6852
Assigned To SHULI4999

Completion Date 5/29/2009

Equipment No. EB-L-FBI-PIP-DUCT
Equipment Description FBI PIPING & DUCT WORK
Location SOILD BUILDING

Comments

completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2273

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 5/15/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments

Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2276

CHECK THE SCRUBER DISK ACTUATOR

Task No. FBIDSKSCRUB-M

Assigned By PORTE3922
Assigned To PORTE3922

Completion Date 5/15/2009

Equipment No. EB-L-FBI-V-SCRB-ACT
Equipment Description FBI SCRUBBER DISK ACTUATOR
Location SOILDS BLDG.

Comments

Task completed.

Employee Code	First Name	Last Name
PORTE3922	JIM	PORTER

WO No. 07-2297

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2297
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2297
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2297
PECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

ments

WO No. 07-2297

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2297

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 4/13/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2298
FBI FLUIDIZING BLOWER - M - O

Task No. FBI-FL-BL-M

Assigned By PORTE3922
Assigned To KELLY6852

Completion Date 5/11/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2299
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By KELLY6852
Assigned To KELLY6852

Completion Date 5/11/2009

Equipment No. EB-L-FBI-HPW-SP-GUN2
Equipment Description FBI ROOF SPRAY GUN #2
Location SOILD BUILDING

Comments
Task has been completed on all equipment listed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2299
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By KELLY6852
Assigned To KELLY6852

Completion Date 5/11/2009

Equipment No. EB-L-FBI-HPW-SP-GUN3
Equipment Description FBI ROOF SPRAY GUN #3
Location SOILD BUILDING

Comments

WO No. 07-2299
F SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By KELLY6852
Assigned To KELLY6852

Completion Date 5/11/2009

Equipment No. EB-L-FBI-HPW-SP-GUN4
Equipment Description FBI ROOF SPRAY GUN #4
Location SOILD BUILDING

Comments

WO No. 07-2299
F F SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By KELLY6852
Assigned To KELLY6852

Completion Date 5/11/2009

Equipment No. EB-L-FBI-HPW-SP-GUN1
Equipment Description FBI ROOF SPRAY GUN #1
Location SOILDS BLDG.

Comments

WO No. 07-2306

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 5/14/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

Task completed.

loyee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2307

CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-01TEMP
Equipment Description HEAT EXCH AIR IN TEMP.1
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-02TEMP
Equipment Description HEAT EXCH AIR OUT TEMP .2
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-03TEMP
Equipment Description WINDBOX TEMP .3
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-04TEMP
Equipment Description BED TEMP .4
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-05TEMP
Equipment Description BED TEMP .5
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-06TEMP
Equipment Description HEAT EXCH GAS IN TEMP .6
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-07TEMP
Equipment Description HEAT EXCH GAS OUT TEMP.7
Location SOILD BUILDING

Comments

WO No. 07-2307
CK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-08TEMP
Equipment Description SCRUBBER GAS OUT TEMP .8
Location SOILD BUILDING

Comments

WO No. 07-2307
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/22/2009

Equipment No. EB-L-FBI-WST-09TEMP
Equipment Description SCRUBBER WATER OUT TEMP .9
Location SOILD BUILDING

Comments

WO No. 07-2308
FBI PREHEAT BLOWER - A - M

Task No. FBIPREHEAT-A

Assigned By FAZO05503
Assigned To FAZO05503

Completion Date 5/15/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2309
CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 4/29/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2313
QUARTERLY EXCEEDENCE REPORT - Q - I

Task No. EXCEED-Q

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/29/2009

Equipment No. EB-L-FBI-CEM-TEST
Equipment Description FBI CEM PERFORMANCE TEST
Location SOILD BUILDING

Comments

Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-10-A-FL
Equipment Description FLUID AIR FLOW (SCFM) .10
Location SOILD BUILDING

Comments

Task completed.

loyee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2314

VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-11-B-LV
Equipment Description BED LEVEL (AVG) .11
Location SOILD BUILDING

Comments

WO No. 07-2314

VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-12-PL-P
Equipment Description CONSTRICTION PLATE PRESSURE .12
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-13-BFL1
Equipment Description BELT #1 FLOW .13
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-14-BFL2
Equipment Description BELT #2 FLOW .14
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-15-BFL3
Equipment Description BELT #3 FLOW .15
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-16-BFL4
Equipment Description BELT #4 FLOW .16
Location SOILDS BLDG.

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-17-WBP
Equipment Description WINDBOX PRES .17
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-18-FBP
Equipment Description FREEBOARD PRESSURE .18
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-19-HEDP
Equipment Description HEAT EXCH D/P .19
Location SOILD BUILDING

Comments

WO No. 07-2314
IFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-20-SDP
Equipment Description SCRUBBER DIFFERENTIAL PRESSURE .20
Location SOILD BUILDING

Comments

WO No. 07-2314
IFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-21-GFL
Equipment Description FUEL (GAS) FLOW (AVG) .21
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-22-O2FL
Equipment Description EXCESS O2 CONCENTRATION .22
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-31-BLVI
Equipment Description BED LEVEL (INSTANT) .31
Location SOILD BUILDING

Comments

WO No. 07-2314
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/19/2009

Equipment No. EB-L-FBI-WST-32-PLP1
Equipment Description CONSTRICTION PLATE PRESSURE(INSTANT) .32
Location SOILD BUILDING

Comments

WO No. 07-2315
FBI SCRUBBER PACKING - Q - M

Task No. FBISCRUBPK-Q

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/18/2009

Equipment No. EB-L-FBI-V-SCRB
Equipment Description FBI-VENTURI SCRUBBER
Location SOILD BUILDING

Comments

Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2327

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 6/15/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

Pump operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2328

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 6/15/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments

Pump on stand-by at this time.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-01TEMP
Equipment Description HEAT EXCH AIR IN TEMP.1
Location SOILD BUILDING

Comments

Task completed on all equipment list.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-02TEMP
Equipment Description HEAT EXCH AIR OUT TEMP .2
Location SOILD BUILDING

Comments

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-03TEMP
Equipment Description WINDBOX TEMP .3
Location SOILD BUILDING

Comments

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-04TEMP
Equipment Description BED TEMP .4
Location SOILD BUILDING

Comments

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-05TEMP
Equipment Description BED TEMP .5
Location SOILD BUILDING

Comments

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-06TEMP
Equipment Description HEAT EXCH GAS IN TEMP .6
Location SOILD BUILDING

Comments

WO No. 07-2329
CK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-07TEMP
Equipment Description HEAT EXCH GAS OUT TEMP.7
Location SOILD BUILDING

Comments

WO No. 07-2329
CK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-08TEMP
Equipment Description SCRUBBER GAS OUT TEMP .8
Location SOILD BUILDING

Comments

WO No. 07-2329
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/22/2009

Equipment No. EB-L-FBI-WST-09TEMP
Equipment Description SCRUBBER WATER OUT TEMP .9
Location SOILD BUILDING

Comments

WO No. 07-2330
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments

Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2330

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2330

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2330
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

Comments

WO No. 07-2330
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2330
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 5/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2331
CK THE SCRUBER DISK ACTUATOR

Task No. FBIDSKSCRUB-M

Assigned By BOYNT7503
Assigned To PORTE3922

Completion Date 6/15/2009

Equipment No. EB-L-FBI-V-SCRB-ACT
Equipment Description FBI SCRUBBER DISK ACTUATOR
Location SOILDS BLDG.

Comments

Task completed.

Employee Code	First Name	Last Name
PORTE3922	JIM	PORTER

WO No. 07-2332

FBI FLUIDIZING BLOWER - M - O

Task No. FBI-FL-BL-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
PORTE3922	JIM	PORTER

WO No. 07-2333
CALIBRATE THE OXYGEN ANALYZER

Task No. FBIOXAN-S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/25/2009

Equipment No. EB-L-FBI-G-SCRB-OXY
Equipment Description FBI OXYGEN ANALYZER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2334
FBI PREHEAT BLOWER - A - M

Task No. FBIPREHEAT-A

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2335
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-HPW-SP-GUN1
Equipment Description FBI ROOF SPRAY GUN #1
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
PORTE3922	JIM	PORTER

WO No. 07-2335
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-HPW-SP-GUN2
Equipment Description FBI ROOF SPRAY GUN #2
Location SOILD BUILDING

Comments

WO No. 07-2335
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-HPW-SP-GUN3
Equipment Description FBI ROOF SPRAY GUN #3
Location SOILD BUILDING

Comments

WO No. 07-2335
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 6/15/2009

Equipment No. EB-L-FBI-HPW-SP-GUN4
Equipment Description FBI ROOF SPRAY GUN #4
Location SOILD BUILDING

Comments

WO No. 07-2357
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments

Task completed on list equipment.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2357

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2357

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2357
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

Comments

WO No. 07-2357
PECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2357
ECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 6/15/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2358

CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 5/29/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments

Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2359

CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 6/29/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments

Task completed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH APR. 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0720	✓			J.J. OK
2	0710	✓			J.J. OK
3	0700	✓			J.J. OK
4	0700	✓			J.J. OK
5	0710	✓			J.J. OK
6	S/B	—			HT
7	S/B	—			HT
8	S/B	—			HT
9	0710	✓			J.J. OK
10	0710	✓			J.J. OK
11	0710	✓			J.J. OK
12	0700	✓			J.J. OK
13	0700	JP			
14	—S/B	—	S/B		Stand By
15	JP 0700	✓	"		JP " "
16	0715	✓	"		JP " "
17	0700	✓			J.J.
18	0700	✓			J.J.
19	0700	✓			J.J. OK
20	0710	✓			J.J. OK
21	0700	✓			JP
22	0710	✓			JP
23	0700	✓			JP
24	0700	✓			[illegible]
25	0700	✓			[illegible]
26	0700	✓			CK
27	0700	✓			CK
28	0700	✓			J.J. OK
29	0700	✓			J.J. OK
30	0700	✓			OK J.J.
31					

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH MAY 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0700	✓			H.B
2	0700	✓			HB
3	0700	✓			HB
4	700	✓			[illegible]
5	0700	✓			[illegible]
6	0700	✓			[illegible]
7	0700	✓			[illegible]
8	0730 SB	—	—	—	SB JP
9	0700	✓			[illegible]
10	0700	✓	—	—	[illegible]
11	0700	✓	—	—	[illegible]
12	0700	✓			[illegible]
13	0700	✓			[illegible]
14	0700	—	—	—	CK
15	0700	—	—	—	HT
16	0700	—	—	—	HT
17	0700	—	—	—	HT
18	0700	—	—	—	HT
19	0700	—	—	—	CK
20	SB				
21	0700 SB	✓			[illegible]
22	0700 SB	✓			[illegible]
23	0700	—	—	—	[illegible]
24	0700	✓	—	—	[illegible]
25	0700	✓	—		[illegible]
26	0700	✓	—	—	[illegible]
27	0700	✓			[illegible] DK
28	0700	✓			[illegible] DK
29	0700	✓			[illegible] DK
30	0700	✓			[illegible] DK
31	0700	✓			[illegible] DK

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH June 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0700	✓			HT
2	0700	✓			HT
3	0700	✓			HT
4	0700	✓			J.T.
5	0700	✓			J.T.
6	0700	✓			J.T.
7	0700	✓			J.T.
8	0700	✓			J.T.
9	0700	✓			J.T.
10	0700	✓			HT
11	0700	✓			HT
12	0700	✓			J.T.
13	0700	✓			J.T.
14	0700	✓			J.T.
15	0700	✓			J.T.
16	S/B	✓			J.T.
17	0730	✓			J.T.
18	0700	✓			J.T.
19	0700	✓			HT
20	0700	✓			HT
21	0700	✓			J.T.
22	0700	✓			J.T.
23	0700	✓			J.T.
24	0700	✓			J.T.
25	0700	✓			J.T.
26	0700	✓			HT
27	0700	✓			HT
28	0700	✓			HT
29	0700	OFFLINE			J.T.
30	0700	✓			J.T.
31	0700	✓			J.T.