Section Five

Quarterly Fluid Bed Incinerator Preventive Maintenance Records July 1, 2009 to September 30, 2009 40 CFR Part 60, Subpart A & O and 40 CFR Part 503

Data Submitted:

- ***FBI-CEM operation records***
- ***Preventive maintenance records***
- ***FBI-Daily equipment inspection log***
- ***FBI-Oxygen analyzer daily calibration records***
- ***FBI-Plume observation log***

Note:
The Fluid Bed Incinerator operates under the 40 CFR Part 69, Subparts A & O and 40 CFR Part 503 regulations. This report satisfies paragraph 61, c of the consent decree. Verifying operation and maintenance of the FBI is in accord with the Fluid Bed Incineration Operation & Maintenance Plan previously submitted. Section 5 also satisfies Section 8 (Preventive Maintenance) of the FBI Operation & Maintenance plan that is different from the Sewerage & Water Board Preventive Maintenance Program.

Hours

Runtime:	691:52:00	92.99%
Downtime:	52:08:00	7.01%
Total:	744:00:00	100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

July 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
07/01/2009 00:00:00	07/14/2009 13:20:00	Incinerator Online	325:20:00		Steven J Robinson
07/14/2009 13:20:00	07/16/2009 17:23:00	Incinerator Offline		52:03:00	Herbert Thomas
07/16/2009 17:23:00	07/17/2009 13:02:00	Incinerator Online	19:39:00		Jawanda Trimont
07/17/2009 13:02:00	07/17/2009 13:04:00	Incinerator Offline		00:02:00	Carl Kelly
07/17/2009 13:04:00	07/17/2009 13:06:00	Incinerator Online	00:02:00		Carl Kelly
07/17/2009 13:06:00	07/17/2009 13:07:00	Incinerator Offline		00:01:00	Carl Kelly
07/17/2009 13:07:00	07/21/2009 12:45:00	Incinerator Online	95:38:00		Carl Kelly
07/21/2009 12:45:00	07/21/2009 12:45:00	System Reset		00:00:00	********
07/21/2009 12:45:00	07/23/2009 07:32:00	Incinerator Online	42:47:00		********
07/23/2009 07:32:00	07/23/2009 07:34:00	Calibration Gas Valve Open		00:02:00	Jawanda Trimont
07/23/2009 07:34:00	08/01/2009 00:00:00	Incinerator Online	208:26:00		Jawanda Trimont

Hours

Runtime:	732:54:00	98.51%
Downtime:	11:06:00	1.49%
Total:	744:00:00	100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

August 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
08/01/2009 00:00:00	08/05/2009 13:22:00	Incinerator Online	109:22:00		Steven J Robinson
08/05/2009 13:22:00	08/05/2009 14:47:00	Incinerator Offline		01:25:00	Herbert Thomas
08/05/2009 14:47:00	08/10/2009 10:55:00	Incinerator Online	116:08:00		Herbert Thomas
08/10/2009 10:55:00	08/10/2009 15:09:00	Incinerator Offline		04:14:00	Jawanda Trimont
08/10/2009 15:09:00	08/11/2009 15:29:01	Incinerator Online	24:20:01		Jawanda Trimont
08/11/2009 15:29:01	08/11/2009 15:30:00	Incinerator Offline		00:00:59	Jawanda Trimont
08/11/2009 15:30:00	08/11/2009 15:32:00	Incinerator Online	00:02:00		Jawanda Trimont
08/11/2009 15:32:00	08/11/2009 15:33:00	Incinerator Offline		00:01:00	Jawanda Trimont
08/11/2009 15:33:00	08/11/2009 15:36:00	Incinerator Online	00:03:00		Jawanda Trimont
08/11/2009 15:36:00	08/11/2009 21:01:01	Incinerator Offline		05:25:01	Jawanda Trimont
08/11/2009 21:01:01	09/01/2009 00:00:00	Incinerator Online	482:58:59		Steven J Robinson

Hours

Runtime:	720:00:00	100.00%
Downtime:	00:00:00	0.00%
Total:	720:00:00	100.00%

Monthly Downtime Report

New Orleans - East Bank WWTP

September 2009

VEOLIA WATER

Start	End	Description	Duration Up	Duration Down	Operator
09/01/2009 00:00:00	10/01/2009 00:00:00	Incinerator Online	720:00:00		Billy Howard

VEOLIA
WATER

FLUID BED INCINERATOR PM REPORT

JULY 1, – SEPTEMBER 30, 2009

DESCRIPTION	NO.of PM COMPLETED
Total Monthly Preventive Maintenance (PM)	85
Total Quarterly Preventive Maintenance (PM)	3
Total Semi-Annual Preventive Maintenance (PM)	17
Total Annual Preventive Maintenance (PM)	2
Total Preventive Maintenance Submitted	**107**

WO No. 07-2366

Ash pump 2 packing

Task No.

Assigned By BOYNT7503
Assigned To EDDY00763

Completion Date 7/24/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

Packing is leaking around this pump and need to be repaired.
24/09 Tried tighting packing before.It does not work.Pump can't be shut down to be fully disassembled.

Employee Code	First Name	Last Name
EDDY00763	CHUCK	EDDY

WO No. 07-2371

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 7/15/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments
Pump #2 in service and operation properly.
Pump #1 on stand-by.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2372
SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 7/15/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments
Pump 1 on stand-by pump,2 operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-01TEMP
Equipment Description HEAT EXCH AIR IN TEMP.1
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-02TEMP
Equipment Description HEAT EXCH AIR OUT TEMP .2
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-03TEMP
Equipment Description WINDBOX TEMP .3
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-04TEMP
Equipment Description BED TEMP .4
Location SOILD BUILDING

nments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-05TEMP
Equipment Description BED TEMP .5
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-06TEMP
Equipment Description HEAT EXCH GAS IN TEMP .6
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-07TEMP
Equipment Description HEAT EXCH GAS OUT TEMP.7
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-08TEMP
Equipment Description SCRUBBER GAS OUT TEMP .8
Location SOILD BUILDING

Comments

WO No. 07-2373
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/23/2009

Equipment No. EB-L-FBI-WST-09TEMP
Equipment Description SCRUBBER WATER OUT TEMP .9
Location SOILD BUILDING

Comments

WO No. 07-2374
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2374
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2374
SPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2374

SPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

Comments

WO No. 07-2374

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2374

INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/22/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2375
CALIBRATE THE W.A.S. FLOW METER

Task No. FBICALWASFM - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 7/14/2009

Equipment No. EB-L-FBI-WAS-FLW-MET
Equipment Description FBI WAS FLOW METER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2376
CHECK THE SCRUBER DISK ACTUATOR

Task No. FBIDSKSCRUB-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 7/16/2009

Equipment No. EB-L-FBI-V-SCRB-ACT
Equipment Description FBI SCRUBBER DISK ACTUATOR
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
SHULI4999	STEVEN	SHULIN

WO No. 07-2377
FBI FLUIDIZING BLOWER - M - O

Task No. FBI-FL-BL-M

Assigned By BOYNT7503
Assigned To KELLY6852

Completion Date 7/15/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Task completed

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2378
FBI PREHEAT BLOWER - A - M

Task No. FBIPREHEAT-A

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 9/25/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments

Not in service at this time.

Employee Code	First Name	Last Name
ZO05503	TIHO	FAZO

WO No. 07-2379

CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 7/29/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Not in service at this time.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2380
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 7/25/2009

Equipment No. EB-L-FBI-HPW-SP-GUN1
Equipment Description FBI ROOF SPRAY GUN #1
Location SOILDS BLDG.

Comments
Replaced the tip.

WO No. 07-2380
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 7/25/2009

Equipment No. EB-L-FBI-HPW-SP-GUN2
Equipment Description FBI ROOF SPRAY GUN #2
Location SOILD BUILDING

Comments
OK

WO No. 07-2380
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 7/25/2009

Equipment No. EB-L-FBI-HPW-SP-GUN3
Equipment Description FBI ROOF SPRAY GUN #3
Location SOILD BUILDING

Comments
Replaced the tip.

WO No. 07-2380
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 7/25/2009

Equipment No. EB-L-FBI-HPW-SP-GUN4
Equipment Description FBI ROOF SPRAY GUN #4
Location SOILD BUILDING

Comments
ok

Employee Code	First Name	Last Name
SHULI4999	STEVEN	SHULIN

WO No. 07-2400
QUARTERLY EXCEEDENCE REPORT - Q - I

Task No. EXCEED-Q

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/ 2/2009

Equipment No. EB-L-FBI-CEM-TEST
Equipment Description FBI CEM PERFORMANCE TEST
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-10-A-FL
Equipment Description FLUID AIR FLOW (SCFM) .10
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-11-B-LV
Equipment Description BED LEVEL (AVG) .11
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-12-PL-P
Equipment Description CONSTRICTION PLATE PRESSURE .12
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-13-BFL1
Equipment Description BELT #1 FLOW .13
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-14-BFL2
Equipment Description BELT #2 FLOW .14
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-15-BFL3
Equipment Description BELT #3 FLOW .15
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-16-BFL4
Equipment Description BELT #4 FLOW .16
Location SOILDS BLDG.

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-17-WBP
Equipment Description WINDBOX PRES .17
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-18-FBP
Equipment Description FREEBOARD PRESSURE .18
Location SOILD BUILDING

Comments

WO No. 07-2401
RIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-19-HEDP
Equipment Description HEAT EXCH D/P .19
Location SOILD BUILDING

Comments

WO No. 07-2401
RIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-20-SDP
Equipment Description SCRUBBER DIFFERENTIAL PRESSURE .20
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-21-GFL
Equipment Description FUEL (GAS) FLOW (AVG) .21
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-22-O2FL
Equipment Description EXCESS O2 CONCENTRATION .22
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-31-BLVI
Equipment Description BED LEVEL (INSTANT) .31
Location SOILD BUILDING

Comments

WO No. 07-2401
VARIFIY COMPUTER READINGS

Task No. FBICALCOMP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/18/2009

Equipment No. EB-L-FBI-WST-32-PLP1
Equipment Description CONSTRICTION PLATE PRESSURE(INSTANT) .32
Location SOILD BUILDING

Comments

WO No. 07-2402
FBI DUCT DAMPERS - Q - O

Task No. FBIDUCT-Q

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 9/25/2009

Equipment No. EB-L-FBI-PIP-DUCT
Equipment Description FBI PIPING & DUCT WORK
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2408
FBI FLUIDIZING BLOWER - A - M

Task No. FBIBLWR-A

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/25/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Not in service at this time.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-FLU-A-DIP
Equipment Description FBI FREEBOARD PRESSURE D/P
Location SOILD BUILDING

Comments
Task completed on all listed equipment.

ployee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-FRBD-P-DP
Equipment Description FBI FREEBOARD PRESSURE D/P
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-FRBD-P-TP
Equipment Description FREEBOARD PRESSURE TAP
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-H-EXCH-A-DP
Equipment Description FBI HEAT EXCHANGER AIR FLOW D/P
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-RACT-P-DP
Equipment Description FBI BED PRESSURE D/P
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-RACT-PLT-DP
Equipment Description FBI CONSTRICTION PLATE D/P
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-V-SCRB-DP
Equipment Description FBI SCRUBBER DIFFERENTIAL PRESSURE
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-WBOX-P-DP
Equipment Description FBI WINDBOX PRESSURE DP
Location SOILD BUILDING

Comments

WO No. 07-2409
CALIBRATE DIFFERENTIAL PRESSURE

Task No. FBICAL - DP - S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. -
Equipment Description
Location -

Comments

WO No. 07-2410
HEATED STACK FILTER - S - I

Task No. FBIHEAT-STK-FLT-S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-CEM-STK-FLT
Equipment Description FBI HEATED STACK FILTER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2411
CALIBRATE THE OXYGEN ANALYZER

Task No. FBIOXAN-S

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/24/2009

Equipment No. EB-L-FBI-G-SCRB-OXY
Equipment Description FBI OXYGEN ANALYZER
Location SOILD BUILDING

Comments

Task completed.

Employee Code	First Name	Last Name
ONE9183	RODNEY	RONNEY

WO No. 07-2412
SCHWING SLUDGE CAKE PUMP (10 & 17)- S - M

Task No. FBISCHW-PMP-S

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/10/2009

Equipment No. EB-L-FBI-SL-F-KSP-(10) NORTH
Equipment Description FBI SLUDGE CAKE PUMP KSP-NORTH
Location SOILDS BLDG.

Comments
On stand-by

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2412
SCHWING SLUDGE CAKE PUMP (10 & 17)- S - M

Task No. FBISCHW-PMP-S

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/10/2009

Equipment No. EB-L-FBI-SL-F-KSP-(17) SOUTH
Equipment Description FBI SLUDGE CAKE PUMP KSP-SOUTH
Location SOILDS BLDG.

Comments
Task completed.

WO No. 07-2413
FBI SCRUBBER PACKING - Q - M

Task No. FBISCRUBPK-Q

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/25/2009

Equipment No. EB-L-FBI-V-SCRB
Equipment Description FBI-VENTURI SCRUBBER
Location SOILD BUILDING

Comments
New packing installed.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-01TEMP
Equipment Description HEAT EXCH AIR IN TEMP.1
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-02TEMP
Equipment Description HEAT EXCH AIR OUT TEMP .2
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-03TEMP
Equipment Description WINDBOX TEMP .3
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-04TEMP
Equipment Description BED TEMP .4
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-05TEMP
Equipment Description BED TEMP .5
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-06TEMP
Equipment Description HEAT EXCH GAS IN TEMP .6
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-07TEMP
Equipment Description HEAT EXCH GAS OUT TEMP.7
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-08TEMP
Equipment Description SCRUBBER GAS OUT TEMP .8
Location SOILD BUILDING

Comments

WO No. 07-2429
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-WST-09TEMP
Equipment Description SCRUBBER WATER OUT TEMP .9
Location SOILD BUILDING

Comments

WO No. 07-2430
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments
Task completed on all equipment listed.

Employee Code	First Name	Last Name
ROONE9183	RODNEY	RONNEY

WO No. 07-2430
SPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2430
PECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2430
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

Comments

WO No. 07-2430
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2430
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 8/24/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2431
CHECK THE SCRUBER DISK ACTUATOR

Task No. FBIDSKSCRUB-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/17/2009

Equipment No. EB-L-FBI-V-SCRB-ACT
Equipment Description FBI SCRUBBER DISK ACTUATOR
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2432
FBI FLUIDIZING BLOWER - M - O

Task No. FBI-FL-BL-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/17/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2433
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/24/2009

Equipment No. EB-L-FBI-HPW-SP-GUN1
Equipment Description FBI ROOF SPRAY GUN #1
Location SOILDS BLDG.

Comments

Task completed on all listed equipment.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2433

ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/24/2009

Equipment No. EB-L-FBI-HPW-SP-GUN2
Equipment Description FBI ROOF SPRAY GUN #2
Location SOILD BUILDING

Comments

WO No. 07-2433
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/24/2009

Equipment No. EB-L-FBI-HPW-SP-GUN3
Equipment Description FBI ROOF SPRAY GUN #3
Location SOILD BUILDING

Comments

WO No. 07-2433
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 8/24/2009

Equipment No. EB-L-FBI-HPW-SP-GUN4
Equipment Description FBI ROOF SPRAY GUN #4
Location SOILD BUILDING

Comments

WO No. 07-2454
ASH PUMP - S - M

Task No. ASHPMP-S

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/10/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments
Pump operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2454
ASH PUMP - S - M

Task No. ASHPMP-S

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/10/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

WO No. 07-2458
SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 8/14/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments
Pump 2 in service operating properly.
Pump 1 on stand-by.

Employee Code	First Name	Last Name
ZO05503	TIHO	FAZO

WO No. 07-2459

SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 8/14/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

Pump 1 on stand-by,pump 2 operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2460

CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-03TEMP
Equipment Description WINDBOX TEMP .3
Location SOILD BUILDING

Comments
Task completed on all listed equipment.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-04TEMP
Equipment Description BED TEMP .4
Location SOILD BUILDING

Comments

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-05TEMP
Equipment Description BED TEMP .5
Location SOILD BUILDING

Comments

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-06TEMP
Equipment Description HEAT EXCH GAS IN TEMP .6
Location SOILD BUILDING

Comments

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-07TEMP
Equipment Description HEAT EXCH GAS OUT TEMP.7
Location SOILD BUILDING

Comments

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-08TEMP
Equipment Description SCRUBBER GAS OUT TEMP .8
Location SOILD BUILDING

Comments

WO No. 07-2460
ECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-09TEMP
Equipment Description SCRUBBER WATER OUT TEMP .9
Location SOILD BUILDING

Comments

WO No. 07-2460
ECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-01TEMP
Equipment Description HEAT EXCH AIR IN TEMP.1
Location SOILD BUILDING

Comments

WO No. 07-2460
CHECK THE COMPUTER DATA LOG RECORDER

Task No. FBICALTEMPS

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-WST-02TEMP
Equipment Description HEAT EXCH AIR OUT TEMP .2
Location SOILD BUILDING

Comments

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-RACT-T-TC4
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #4
Location SOILD BUILDING

Comments
Task completed on all listed equipment.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-RACT-T-TC5
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE #5
Location SOILD BUILDING

Comments

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-RACT-T-TCC
Equipment Description FBI BED TEMPERATURE THERMAL COUPLE CTRL
Location SOILD BUILDING

Comments

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-V-SCRB-TC1
Equipment Description FBI SCRUBBER THERMAL COUPLE #1
Location SOILD BUILDING

Comments

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-V-SCRB-TC2
Equipment Description FBI SCRUBBER THERMAL COUPLE #2
Location SOILD BUILDING

Comments

WO No. 07-2461
INSPECT THRMAL COUPLES

Task No. FBICALTRCP

Assigned By BOYNT7503
Assigned To ROONE9183

Completion Date 9/23/2009

Equipment No. EB-L-FBI-V-SCRB-TC3
Equipment Description FBI SCRUBBER THERMAL COUPLE #3
Location SOILD BUILDING

Comments

WO No. 07-2462
ECK THE SCRUBER DISK ACTUATOR

Task No. FBIDSKSCRUB-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 9/16/2009

Equipment No. EB-L-FBI-V-SCRB-ACT
Equipment Description FBI SCRUBBER DISK ACTUATOR
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2463
FBI FLUIDIZING BLOWER - M - O

Task No. FBI-FL-BL-M

Assigned By SHULI4999
Assigned To KELLY6852

Completion Date 9/16/2009

Equipment No. EB-L-FBI-FLU-A-BLWR
Equipment Description FBI FLUID AIR BLOWER
Location SOILD BUILDING

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2464
CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 8/28/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Not in service at this time.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2465
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/23/2009

Equipment No. EB-L-FBI-HPW-SP-GUN1
Equipment Description FBI ROOF SPRAY GUN #1
Location SOILDS BLDG.

Comments
Task completed.

Employee Code	First Name	Last Name
KELLY6852	CARL	KELLY

WO No. 07-2465
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/23/2009

Equipment No. EB-L-FBI-HPW-SP-GUN2
Equipment Description FBI ROOF SPRAY GUN #2
Location SOILD BUILDING

Comments

WO No. 07-2465
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/23/2009

Equipment No. EB-L-FBI-HPW-SP-GUN3
Equipment Description FBI ROOF SPRAY GUN #3
Location SOILD BUILDING

Comments

WO No. 07-2465
ROOF SPRAY SYSTEM - M - O

Task No. FBIROOFSPRY-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/23/2009

Equipment No. EB-L-FBI-HPW-SP-GUN4
Equipment Description FBI ROOF SPRAY GUN #4
Location SOILD BUILDING

Comments

WO No. 07-2479

ASH PUMP - S - M

Task No. ASHPMP-S

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 9/25/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments

Pump operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2479

ASH PUMP - S - M

Task No. ASHPMP-S

Assigned By BOYNT7503
Assigned To SHULI4999

Completion Date 9/25/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments

WO No. 07-2480
SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/14/2009

Equipment No. EB-L-FBI-A-PMP-1
Equipment Description FBI ASH PUMP 1
Location SOILDS BUILDING

Comments
Pump #2 in service and operating properly.
Pump #1 on stand-by.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2481
SERVICE THE ASH PUMPS - M - M

Task No. FBIASHPAK-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/14/2009

Equipment No. EB-L-FBI-A-PMP-2
Equipment Description FBI ASH PUMP 2
Location SOILDS BUILDING

Comments
Pump one is in stand-by and two is operating properly.

Employee Code	First Name	Last Name
FAZO05503	TIHO	FAZO

WO No. 07-2482
CHECK FBI PREHEAT BLOWER

Task No. FBIPREHEAT-M

Assigned By BOYNT7503
Assigned To FAZO05503

Completion Date 9/28/2009

Equipment No. EB-L-FBI-PRE-H-BLW
Equipment Description FBI PREHEAT BLOWER
Location SOILDS BLDG.

Comments
Not in service at this time.

Employee Code	First Name	Last Name
AZO05503	TIHO	FAZO

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH July 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0700	✓			CK
2	0700	✓			J.A.
3	0700	✓			H.T.
4	0700	✓			H.T.
5	0700	✓			H.T.
6	0700	✓			H.T.
7	0700	✓			J.A.
8	0700	✓			J.A.
9	0700	✓			J.A.
10	0700	✓			H.T.
11	0700	✓			H.T.
12	0700	✓			H.T.
13	0700	✓			H.T.
14	0700	✓			HT
15	OFFLINE				J.A.
16	OFFLINE	X			J.A.
17	Stand-by	X			CK
18	0700	✓			H.T.
19	0700	✓			H.T.
20	0700	✓			H.T.
21	0700	✓			H.T.
22	0700	✓			CK
23	0700	✓			H.T.
24	0700	✓			H.T.
25	0700	✓			H.T.
26	0700	✓			H.T.
27	0700	✓			H.T.
28	0730	✓			SK
29	0700	✓			H.T.
30	0700	✓			CK
31	0700	✓			J.A.

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH Aug. 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0700	✓			J.J. OK
2	0700	✓			J.J. OK
3	0700	✓			J.J. OK.
4	0715	✓			STS OK
5	0700	✓			H.T.
6	0700	✓			H.T.
7	0700	✓			J.J. OK
8	0700	✓			J.J. OK
9	0700	✓			J.J. OK.
10	0715	✓			STS OK
11	0710	✓			STS OK
12	0700	✓			J.T.
13	0700	✓			J.T.
14	0700	✓			J.T.
15	0700	✓			J.T.
16	0700	✓			J.J.
17	0700	✓			J.J.
18	0700	✓			J.T.
19	0700	✓			J.T.
20	0700	✓			J.T.
21	0700	✓			J.T.
22	0700	✓			H.T.
23	1130	✓			H.T.
24	0700	✓			J.J.
25	0700	✓			J.J.
26	0700	✓			J.J.
27	0710	✓			J.J.
28	0700	✓			J.T.
29	0700				J.T.
30	0700				J.T.
31	0700	✓			J.T.

FLUID-BED INCINERATOR

PLUME OBSERVATION DAILY RECORD

MONTH Sept. 2009

DAY	TIME Oberservered	PLUME White	PLUME Black	COLOR Other	COMMENTS
1	0700	✓			[illegible]
2	0700	✓			[illegible]
3	0700	✓			[illegible]
4	0700	✓			[illegible]
5	0700	✓			[illegible]
6	0700	✓			[illegible]
7	0700	✓			[illegible]
8	0700	✓			[illegible]
9	0700	✓			[illegible]
10	0700	✓			[illegible]
11	0700	✓			[illegible]
12	0700	✓			[illegible]
13	0700	✓			[illegible]
14	0700	✓			[illegible]
15		✓			
16	0700	✓			[illegible]
17	0700	✓			[illegible]
18	0700	✓			[illegible]
19	0700	✓			[illegible]
20	0700	✓			[illegible]
21	0700	✓			[illegible]
22	0700	✓			[illegible]
23	0700	✓			[illegible]
24	0700	✓			[illegible]
25	0700	✓			[illegible]
26	0700	✓			[illegible]
27	0700	✓			[illegible]
28	0700	✓			[illegible]
29	0700	✓			[illegible]
30	0830	✓			[illegible]
31					