

BLD Contract 30251

Submitted 9.16.24

(~95% COMPLETE)

Restoration On Going next 2 weeks

Working to finalize restoration

MH work is nearing completion on this contract.

Remaining work on this contract 3000 Washington Ave, 2500 S Tonti St CIPP (need defined scope – both segments are PVC but some service work maybe required – LAT CIPP, LAT Repairs)

Segments near Five-oh-Fore Golf – Work TBD – tried to line the two short segments 3800 Euprosine St and S Broad Street and the lining crew reported clear water coming into the manhole (possible leak in the area). Access Issues to CCTV S Broad St (inside fence, heavy equipment in area, site conditions are rough for a CCTV truck to access these manholes).