




State of Louisiana
Louisiana Department of Health
Office of Public Health

October 20, 2016



TO: Vincent P, Jr Fouchi
8800 S Claiborne Ave
New Orleans, LA 70118

Re: **Notice of lead and copper sample results**
New Orleans Algiers Water Works
PWS ID #: LA1071001

Dear Mr. Fouchi,

Attached are the lead and copper sampling results for the above named water system. Based on the sampling results, the lead action level was exceeded at one or more sampling locations. A Lead consumer notice shall be distributed to each consumer who participated in the sampling event. **The notice must be delivered to those customers with an individual lead action level exceedance (result > 15 ppb) within 14 days of receipt of this letter. The notice must be delivered to those remaining customers below the lead action level within 30 days of receipt of this letter.** Blank consumer notice forms are attached for your convenience. Please note that one form is used specifically for those customers below the lead action level and a separate form is used specifically for those customer(s) above the action level.

Further instructions are included in the attached certification form. The certification form and a copy of one of the consumer notices must be submitted to the State within 90 days of distributing the notices. Failure to distribute lead consumer notice will result in a violation.

The water system 90th percentiles for lead and copper can not exceed 15 ppb and 1.3 ppm, respectively. This office has calculated the 90th percentile values for the water system and they are both below their respective action levels. The following are the 90th Percentile Values for the water system:

The 90th Percentile for Lead is 3 ppb

The 90th Percentile for Copper is 0.1 ppm

The water system has been scheduled to continue sampling every three years. The next monitoring period will be June through September 2019. This office will forward information to the water system related to the next sampling event at that time. Please keep these results for your records. If this office can be of further assistance, please call me at 225-342-7471. Further information can also be found at www.dhh.la.gov/safedrinkingwater.

Respectfully,

A handwritten signature in cursive script that reads "Jeremy Harris".

Jeremy Harris
Compliance Engineer
LDH/OPH Engineering Services